



ARKANSAS
Department of Environmental Quality

November 4, 2011

City of Alma - WWTP
Attention: Mark Yardley
811 Fayetteville Avenue
Alma, AR 72921

RE: NPDES Permit Number AR0021466, AFIN 17-00059

Dear Mr. Yardley:

A recent review of the NPDES file for **City of Alma - WWTP** has revealed the following violations for the monitoring period ending **08/31/2011**.

DISCHARGE NUMBER	PARAMETER	VIOLATION	LIMIT	UNITS
001-A	BOD5	30.7 Mo Avg	30 Mo Avg	mg/L
001-A	BOD5	53.3 7 Day Avg	45 7 Day Avg	mg/L
001-A	TSS	50.3 7 Day Avg	45 7 Day Avg	mg/L

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit require you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Please refer to NPDES Permit Number **AR0021466** and AFIN **17-00059** in any written correspondence to ADEQ. Should you have any questions, feel free to call 501-682-0631 or e-mail meints@adeq.state.ar.us.

Sincerely,

René E. Meints
Enforcement Analyst
Water Division Enforcement Branch