

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021466 Discharge Number: 001-A

Facility: City of Alma

Address: 811 Fayetteville Ave

City: Alma State: AR Zip: 72921

Contact: Mark Yardley Phone: 479-632-2254

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
06-30-17	BOD Monthly AV		30.15 mg/L	30 mg/L

We feel this problem was due to:

The proliferation of algae due to warm weather increasing the TSS and BOD.

We plan on correcting the problem in this manner:

The City has engaged Mark Gross of Morrison Shipley Engineering to assess and recommend a corrective action plan.

Time estimated that it will take to correct problem:

After completion of the assessment a timeline for correction will be established.

Sincerely,



Authorized Signature

07-25-17

Date