

ADEQ

ARKANSAS
Department of Environmental Quality

June 8, 2012

Mark Yardley
Alma Waste Waste Treatment Plant
811 Fayetteville Ave, Suite A
Alma, AR 72921

RE: NPDES Permit No. AR0021466, AFIN No. 17-00059

Dear Mr. Yardley:

A recent review of the NPDES file for the City of ALMA has revealed the following violations for the monitoring period ending June 30, 2010.


<u>OUTFALL</u>	<u>PARAMETER</u>	<u>VIOLATION</u>	<u>LIMIT</u>	<u>UNITS</u>
001A	Nitrogen(MO AV)	10.6	5	mg/L
001A	Nitrogen(DA AV)	15.8	7.5	mg/L

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit require you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

No NCR has been received for this violation per our records. Please submit an NCR Report by **September 27, 2010**.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me by phone at 501-682-0636 or e-mail at stowe@adeq.state.ar.us. Please refer to NPDES Permit AR0021466 and AFIN 17-0059 in any written correspondence to ADEQ.

Sincerely,



Billy Stowe
Enforcement Analyst
Water Enforcement Branch
Water Division

ENFORCEMENT CODING SHEET

SCREEN ID ENACS

AR0021466

ALMA, City of

Enforcement action code

03 (warning letter)

Enforcement action date

6/30/2010

Action issued by

State

Enforcement Docket No.

Violation Type

E3 Specific effluent violations

=====

SCREEN ID EAKS

<u>DSDG</u>	<u>LTYP</u>	<u>PARM</u>	<u>MLOC</u>	<u>SEAN</u>	<u>MODN</u>	<u>MVDT</u>
001A	F	00610	1	0	0	06/30/10