

**From:** Trotta, Jacqueline  
**To:** [mark@cityofalma.org](mailto:mark@cityofalma.org)  
**Subject:** RE: NetDMR COR Submission Received for: AR0021466  
**Date:** Monday, August 28, 2017 11:57:00 AM

---

Mr. Yardley,

I received the Non-compliance reports for the following permitted effluent limit violations:

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value
05/31/2017	001-A	BOD, 5-day, 20 deg. C, MO AVG, lb/d	437.9	<b>492.6</b>
05/31/2017	001-A	BOD, 5-day, 20 deg. C, MO AVG, mg/L	30	<b>47.4</b>
05/31/2017	001-A	BOD, 5-day, 20 deg. C, 7 DA AVG, mg/L	45	<b>87.7</b>
06/30/2017	001-A	BOD, 5-day, 20 deg. C, MO AVG, mg/L	30	<b>30.2</b>

In regard to the 7/14/17, Corrective Action Plan (CAP); we look forward to receiving the 1st CAP progress report (due 11/30/17).

Thanks,

Jacqueline Trotta  
Enforcement Analyst  
Office of Water Quality  
Arkansas Department of Environmental Quality  
5301 Northshore Drive  
North Little Rock, AR 72118  
501-682-0632