

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021466 Discharge Number: 001-A

Facility: City of Alma

Address: 811 Fayetteville Ave

City: Alma State: AR Zip: 72921

Contact: Mark Yardley Phone: 479-632-2254

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
12-31-12	BOD MO AV		51.5 mg/l	30 mg/l
12-31-12	TSS MO AV		31.8 mg/l	30 mg/l
12-5-12	BOD 7 DA AVG		70.0 mg/l	45 mg/l
12-12-12	BOD 7 DA AVG		64.0 mg/l	45 mg/l

We feel this problem was due to:

We are still confident that extreme algae growth was the cause of the high BOD and TSS. Low system flows exacerbated the problem.

We plan on correcting the problem in this manner:

The problem has been corrected. The cold weather has reduced algae growth.
All samples collected in the month of January are in compliance.

Time estimated that it will take to correct problem:

The problem has been corrected

Sincerely,

Mark Yardley
Authorized Signature


01-28-13
Date



ALMA WATER DEPARTMENT
811 Fayetteville Ave.
Alma, AR 72921

FORT SMITH, AR 729

31 JAN 2019 PM 1 T



Quality on Tap

724443317

