

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021466 Discharge Number: 001-A

Facility: City of Alma

Address: 811 Fayetteville Ave

City: Alma State: AR Zip: 72921

Contact: Mark Yardley Phone: 479-632-2254

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
11-31-13	BOD MO AV		44.3 mg/l	30 mg/l
11-26-13	BOD 7 DA AVG		46.3 mg/l	45 mg/l

**We feel this problem was due to:**

We are not absolutely certain what caused the increase in BOD. However, we believe that the cold weather caused the remaining algae to die off and contributed to the higher BOD.

**We plan on correcting the problem in this manner:**

We are continuing to feed a product called BEF to enhance biological activity. The sample results for December are all in compliance and improving.

**Time estimated that it will take to correct problem:**

The effluent is now in compliance.

Sincerely,


  
Authorized Signature

12-31-13  
Date



**ALMA WATER DEPARTMENT**  
811 Fayetteville Ave.  
Alma, AR 72921

NORTHWEST AR PAID  
AR 727 2 1  
03 JUN 2017



ADEQ  
Enforcement Division  
5301 Northshore Dr  
North Little Rock, AR 72118-5317

Quality on Tap

721185317

