

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0021466 Discharge Number: 001-A

Facility: City of Alma

Address: 811 Fayetteville Ave

City: Alma State: AR Zip: 72921

Contact: Mark Yardley Phone: 479-632-2254

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
11-30-15	BOD Monthly AV		38.31 mg/l	30 mg/l

We feel this problem was due to:

We believe that the cold weather and higher flows reduced the beneficial biological activity.

We plan on correcting the problem in this manner:

We are feeding a product called BEF to reduce BOD. The first few sample results for December were still higher.

The remaining December samples are in compliance and improving.

Time estimated that it will take to correct problem:

The first 2 samples in December will cause a 7 day average exceedance for BOD. However, the effluent is now in compliance.

Sincerely,


 Authorized Signature

12-17-15
 Date



ALMA WATER DEPARTMENT
811 Fayetteville Ave.
Alma, AR 72921

NW ARKANSAS AR 727

21 DEC 2015 PM 2 T

Happy
Holidays



ADEQ
Enforcement Division
5301 Northshore Dr
North Little Rock, AR 72118-5317

