

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021466 Discharge Number: 001-A

Facility: City of Alma

Address: 811 Fayetteville Ave

City: Alma State: AR Zip: 72921

Contact: Mark Yardley Phone: 479-632-2254

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
10-31-14	BOD MO AV		31.3 mg/l	30 mg/l

We feel this problem was due to:

We believe that the cold weather caused
the remaining algae to die off and contributed to the higher BOD.

We plan on correcting the problem in this manner:

We are continuing to feed a product called BEF to enhance biological activity. The sample results for November are all in
compliance and improving.

Time estimated that it will take to correct problem:

The effluent is now in compliance.

Sincerely,



Authorized Signature

11-21-14
Date



ALMA WATER DEPARTMENT
811 Fayetteville Ave.
Alma, AR 72921

NORTHWEST AR P&DF
AR 727 2 L
24 NOV 2014 PM



Quality on Tap

7211835317

