

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021466 Discharge Number: 001-A

Facility: City of Alma

Address: 811 Fayetteville Ave

City: Alma State: AR Zip: 72921

Contact: Mark Yardley Phone: 479-632-2254

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
03-31-14	TSS		30.7 mg/l	30.0 mg/l

We feel this problem was due to:

Excessive Algae growth due to warmer weather

We plan on correcting the problem in this manner:

Began adding Earthtech algaecide

Time estimated that it will take to correct problem:

The samples in April are within the limits. Algaecide is working.


Sincerely,


Authorized Signature

04-22-14
Date



ALMA WATER DEPARTMENT
811 Fayetteville Ave.
Alma, AR 72921



Quality on Tap

7211695317 R015

