

**Sanitary Sewer Overflow Monthly Report**

**POST**  
SEP 21 2012

Facility Name: City of Alma

Permit Number: AR0021466 Reporting Period (Month/Year): August 2012  
 No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions

Cause(s) of SSO	SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact	CR-Creek/Stream/River (please specify)
E-Equipment Failure	G-Grease	OHHC-Observed or Evidence of Human Contact	DI-Ditch
HC-Hydro Clean	L,F-Line Failure/Break	EHK-Evidence of Fish Kill	DR-Drop Inlet
R-Rainfall	RG-Roots & Grease	EC-Environmental Cleanup	GR-Ground Surface
RO-Roots	V-Vandalism	HC-Hydro Cleaned	PA-Paved Area
		HR-Hand Rodded	CB-Contained in Building
		EN-Referred to Engineering	
		PN-Public Notification	

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Ultimate Discharge Location
25 Highway 64 West	32-4	8/10/2012	8/10/2012	2000	RG	NEAH	WO	DI
Behind 317 Collum Lane West	50-E2	8/21/2012	8/21/2012	12600	D,L,F	NEAH	WO	CR

Signature of Cognizant or Ranking Official

*M. P. Stovall*

Date 9-4-12

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."