

Toups, Tiana

From: Toups, Tiana
Sent: Wednesday, February 16, 2022 11:33 AM
To: 'steve@vbm.org'
Subject: DMR Violations

Mr. Dufrense,

The Division of Environmental Quality (DEQ) has performed a review of the Discharge Monitoring Reports (DMRs) submitted in accordance with the Permit for the City of Van Buren (AR0021482). The review revealed that Ammonia Nitrogen (NH₃-N) was reported above the reportable limits for the following:

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
10/31/2021	001-B	Nitrogen, ammonia total [as N], MO AVG, mg/L	5	8.5	70%
10/31/2021	001-B	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	7.5	20.8	177%
09/30/2021	001-B	Nitrogen, ammonia total [as N], MO AVG, lb/d	166.8	267	60%
09/30/2021	001-B	Nitrogen, ammonia total [as N], MO AVG, mg/L	5	15.6	212%
09/30/2021	001-B	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	7.5	28	273%

The reported amount is a violation of Part 1, Section A of the Permit.

Non-compliance reports with corrective actions were received. Any violation of the Permit is subject to enforcement action which may include a civil penalty.

If you have any questions or need additional information, please don't hesitate to contact me.

Thank you for your attention to this matter.

Tiana Toups | Enforcement Analyst
Division of Environmental Quality | Office of Water Quality
Enforcement Branch

5301 Northshore Drive | North Little Rock, AR 72118
t: 501.682.0699 | e:Tiana.Toups@adeq.state.ar.us



ARKANSAS
ENERGY & ENVIRONMENT