

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021482 Discharge Number: 001

Facility: Van Buren Main Plant

Address: 1401 Port Road

City: Van Buren State: AR Zip: 72957

Contact: Steve Dufresne, Director of Utilities Phone: 479-474-5067

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/9-13/16	Ammonia Nitrogen		15.6	7.5 Day/Average
5/16-20/16	Ammonia Nitrogen		8.99	7.5 Day/Average
May-16	Ammonia Nitrogen		5.08	5 Monthly Average

We feel this problem was due to:

Combination of rain and not enough air in pond. Lost solids due to rain.

We plan on correcting the problem in this manner:

The operator started another blower utilizing 3 blowers instead of two. Rebuilding solids in plant.

Time estimated that it will take to correct problem:

Two weeks, plant is currently in compliance.

Sincerely,



Authorized Signature

Date

