

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0021482 Discharge Number: 001

Facility: City of Van Buren Main Plant

Address: (Plant) 1401 Port Road

City: Van Buren State: AR Zip: 72956

Contact: Steve Dufresne, Director of Utilities Phone: 479-474-5067

| Date of Non-Compliance | Parameter Exceeded | Quantity or Loading | Quality or Concentration | Permit Limits |
|------------------------|-------------------------------------|---------------------|--------------------------|---------------|
| 10/2-8/16 | Ammonia Nitrogen 7-Day Avg. mg/l | | 11.61 mg/l | 7 mg/l |
| | | | | |
| | | | | |

We feel this problem was due to:

The WWTP is still experiencing maintenance issues with the Aeration system blowers and diffusers.

Repairs to the diffuser system also required that blowers be turned off for repairs.

Damaged baffle curtains are causing short cuircuiting

We plan on correcting the problem in this manner:

Diffuser System had more repairs at the end of September and was completed the first of October


Curtain has been repaired.

Time estimated that it will take to correct problem:

Diffuser system and Baffle curtain have been repaired and working properly as of 10/17/16.

WWTP is currently in compliance

Sincerely,


Authorized Signature

11-21-2016
Date