

Farmer, Sandra

From: Farmer, Sandra
Sent: Wednesday, May 27, 2015 10:55 AM
To: 'Steve Dufresne'
Subject: RE: 210 Woodrow street SSO compliant

Thank you Steve.

Sandra Farmer
ADEQ Enforcement Analyst

From: Steve Dufresne [<mailto:steve@vbmunicipal.org>]
Sent: Wednesday, May 27, 2015 10:52 AM
To: Farmer, Sandra
Subject: RE: 210 Woodrow street SSO compliant

On Tuesday May 26, 2015 ,VBMU Line Maintenance crews responded to an SSO complaint at 2105 Woodrow, the crews checked the sewer mains and Manholes and the customers open cleanout and did not observe a SSO or evidence of an SSO.

On Wednesday May 27, 2015, VBMU Line Maintenance Supervisor and crew went back to 2105 Woodrow this morning, they did not observe an actual SSO, they observed evidence of an SSO from the customers open cleanout , Although we did not actually observe a SSO, we will submit a report. we do not know the exact time that the SSO occurred, or the amount of the SSO (estimate less than 100 gallons). The crew will disinfect with a liquid disinfectant/deodorizer, then apply lime to the area, and rake up any leftover debris.

Steve Dufresne
Director of Utilities
Van Buren Municipal Utilities
vbmunicipal.org



From: Farmer, Sandra [<mailto:farmers@adeq.state.ar.us>]
Sent: Wednesday, May 27, 2015 9:55 AM
To: steve@vbmunicipal.org
Cc: Farmer, Sandra
Subject: 210 Woodrow street SSO compliant

Hi Steve,

I am sending you this email to confirm our conversation of May 27, 2015. On this call we discussed the SSO compliant for 2105 Woodrow Street. I will need for you to respond to this email when you find out the information involving 2105 Woodrow Street. Let me know how you answered the compliant, if, the city manholes were involved, which ones. Let me know if you had any cleanup of a contaminated area, what was the disinfectant used, how much, where that was located. Let me know if you had to advise that homeowner of a property cleanout that created an overflow, etc. Thank you very much Steve. I look forward to hearing from you on this issue.

Sandra J Farmer
Enforcement Analyst – Water Division
Arkansas Department of Environmental Quality
5301 Northshore Drive
North Little Rock, Arkansas 72118
501 682 7399