

VAN BUREN MUNICIPAL UTILITIES

"Providing Water, Sewer, and Sanitation Services"

2806 Bryan Road / P.O. Drawer 1269

Van Buren, Arkansas 72957

479-474-5067 / Fax 479-471-8969

Steve Dufresne, Director

November 20, 2012

Arkansas Department of Environmental Quality
NPDES Enforcement Division
5301 Northshore Drive
North Little Rock, AR 72118-5317

Re: Van Buren Main Plant, Permit # AR0021482


Dear Sirs:

Please be advised the above named plant exceeded the monthly average concentration limit for BOD5 for the month of November 2012;

The Monthly Average Concentration for BOD5 was 33mg/L.

We have been doing some adjusting on the diffusers and we have reseeded the plant to try to get the plant back into compliance. We have a wastewater circuit writer from Arkansas Rural Water Association coming to give us ideas on how to get the plant back into compliance.

If you have any questions please let me know.


Sincerely,
Steve Dufresne
Director of Utilities

Cc: Correspondence file, Main Plant file

Serving Van Buren and Crawford County since 1893