

VAN BUREN MUNICIPAL UTILITIES

"Providing Water, Sewer, and Sanitation Services"

2806 Bryan Road / P.O. Drawer 1269

Van Buren, Arkansas 72957

479-474-5067 / Fax 479-471-8969

October 17, 2012

Arkansas Department of Environmental Quality

NPDES Enforcement Division

5301 Northshore Drive

North Little Rock, AR 72118-5317

Re: Van Buren Main Plant, Permit # AR0021482


Dear Sirs:

Please be advised that the above named plant exceeded the monthly average concentration limit for Ammonia Nitrogen (NH₃-N) during the month of September 2012; the Monthly Average Concentration was 10.7 mg/L, and the 7 DA AVG was 18 mg/L.

Currently, we are investigating corrective procedures.

If you have any questions please let me know.

Sincerely,



Steve Dufresne

Director of Utilities

Cc: Correspondence file, Main Plant file

