


CITY OF VAN BUREN Sanitary Sewer Overflow Monthly Report

Facility Name: MAIN PLANT Permit Number: AR0021482 Reporting Period (Month/Year): MAY 2012

No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions				
Cause(s) of SSO		SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact	WO-Work Order	CR-Creek/Stream/River (please specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure/Break	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots & Grease		HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Ultimate Discharge Location
105 S. 42ND	801	5-15-2012	5-15-2012	25	G	NEAH	HC	PA
1308 N. 27TH	IN BLDNG	5-29-12	5-29-12	100	R	OEHC	HC	CB



6/21/12
Date

Signature of Cognizant or Ranking Official
 "I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

VAN BUREN MUNICIPAL UTILITIES

“Providing Water, Sewer, and Sanitation Services”

2806 Bryan Road / P.O. Drawer 1269

Van Buren, Arkansas 72957

479-474-5067 / Fax 479-471-8969

Gary Smith, Director

June 18, 2012

Arkansas Department of Environmental Quality

NPDES Enforcement Division

5301 Northshore Drive

North Little Rock, AR 72118-5317

Re: Van Buren Main Plant, Permit # AR0021482

Dear Sirs:

Please be advised that the above named plant exceeded the monthly average concentration limit for Ammonia Nitrogen (NH₃-N) during the month of May 2012; the Monthly Average Concentration was 14 mg/L, and the Monthly Average Loading was 223 lb/d.

The plant is currently in compliance.

If you have any questions please let me know.

Sincerely,


Steve Dufresne
Operations Superintendent

Cc: Correspondence file, Main Plant file