

**BYPASS/OVERFLOW NCR REPORT**

Send Overflow Report to:

**ADEQ  
P O Box 8913  
Little Rock, AR 72219  
Phone: 1-501-682-0633  
Fax: 1-501-682-0910**

Facility Permit Number: AR0021580

Facility Name: CITY OF OSCEOLA

Date Overflow Began: 12/28/15

Date Overflow Ended: \_\_\_\_\_

Volume: (Type "unknown" if applicable, or give an estimate)

(1.) UNKNOWN

Environmental Damage: NONE

Correction Action Taken: (Short-term and long-term action, including clean-up and any plans to reinstate I&L)

(1.) Cleaned + hydro washed area  
keeping an eye on area to ensure area doesn't  
have any sanitary items.

Description: (Give address, manhole number-if numbered, include where the overflow went, yard, ditch, stream, storm sewer, building or other)

(1.) Manhole on corner of Airport Rd.

Cause of Overflow:

(1.) Heavy Rainfall

Reported By: Resident

(After the overflow/bypass is detected, this completed fax may be sent to ADEQ within 24 hours, as the initial report. The final report must have original signature by cognizant official and sent to ADEQ within 5 days of start of overflow.)

Date Reported: 12/28/15