

BYPASS/OVERFLOW NCR REPORT

Send Overflow Report to:

ADEQ
P O Box 8913
Little Rock, AR 72219
Phone: 1-501-682-0633
Fax: 1-501-682-0910

Facility Permit Number: AR0021580

Facility Name: CITY OF OSCEOLA

Date Overflow Began: 2/18/18

Date Overflow Ended: 2/18/18

Volume: (Type "unknown" if applicable, or give an estimate)

(1.) unknown

Environmental Damage: NONE

Correction Action Taken: (Short-term and long-term action, including clean-up and any plans to reinitiate I&I.)

(1.) mainly rainwater but still cleaned with hydro machine.

Description: (Give address, manhole number-if numbered. Include where the overflow went, yard, ditch, stream, storm sewer, building or other)

(1.) Airport Road
Water went into yard and ditch

Cause of Overflow:

(1.) Excessive rainfall. Also had a float ball problem at lift station

Reported By: Brandon Haynes

(After the overflow/bypass is detected, this completed fax may be sent to ADEQ within 24 hours, as the initial report. The final report must have original signature by cognizant official and sent to ADEQ within 5 days of start of overflow.)

Date Reported: 2/19/18