

CITY OFFICIALS:

DICKIE KENNEMORE, MAYOR
MIKE GIBSON, MUNICIPAL JUDGE
DON BETTERTON, CITY ATTORNEY
LYNDA WELLS, CLERK / TREASURER

CITY COUNCIL:

JOE GUY
OTTIS RAPER
JEANETTE WALKER
LINDA WATSON
LUTHER WHITFIELD
GENE COX



December 11, 2012

Arkansas Department of
Environmental Quality
NPDES Enforcement Section
5301 N. Shore DR.
North Little Rock, Arkansas 72118

RE: NPDES PERMIT NO. AR0021580
Discharge Monitoring Report for NOVEMBER, 2012

Enclosed is the Discharge Monitoring Report for the City of Osceola for the month
November, 2012.

The permit conditions were met during the month November, for BOD₅,
TSS, PH, Fecal Coliform, Dissolved Oxygen (DO).
A total of 06 samples were taken for each during the month of November, 2012

One sample was taken during the month of November, 2012 for
Phosphorus, total (as P) and
One sample was taken during the month of November, 2012 for
Nitrite plus nitrate total 1 det. (as N)

No samples were taken the week ending November 24, 2012 and December 01, 2012
due to no flow from the wastewater treatment plant.


Also enclosed with the regular November, 2012 (DMR) is the Sanitary Sewer Overflow
Monthly Report, (SSO), with 00 overflow's for the month of November, 201

Thanks,

James N. Carlock
WWTP SUPT.
Enclosure

City of Osceola
@ James Carlock
P O Box 443
303 West Hale
Osceola, AR 72370

CERTIFIED MAIL™



7002 3150 0001 9660 3582

Hasler

12/11/2012

US POSTAGE

\$06.75⁰⁰



ZIP 72370
011D11627215

ADEQ
Arkansas Department of Environmental Quality
5301 N. Shore DR.
North Little Rock, Arkansas 72118-5317

