



**TOXICITY REDUCTION EVALUATION  
ACTIVITY REPORT  
SEARCY WASTEWATER TREATMENT PLANT  
OUTFALL 001 (AR0021601)  
THIRD QUARTER 2016**

**OCTOBER 31, 2016**

---

TOXICITY REDUCTION EVALUATION  
ACTIVITY REPORT  
SEARCY WASTEWATER TREATMENT PLANT  
OUTFALL 001 (AR0021601)  
THIRD QUARTER 2016

Prepared for:

Searcy Wastewater Treatment Plant  
PO Box 1319  
Searcy, AR 72145

Prepared by:

FTN Associates, Ltd.  
3 Innwood Circle, Suite 220  
Little Rock, AR 72211

FTN No. 15350-1096-001

October 31, 2016

## TABLE OF CONTENTS

1.0	SUMMARY AND CONCLUSIONS .....	2
2.0	INTRODUCTION .....	2
3.0	TRE ACTIVITIES .....	2
3.1	Routine Biomonitoring and Effluent Screening .....	2
4.0	FOLLOW UP Testing.....	4
5.0	LITERATURE CITED .....	5

## LIST OF TABLES

Table 1	Summary of chronic toxicity tests using <i>C. dubia</i> conducted on Outfall 001 samples collected during 2016.....	3
Table 2	Routine water chemistry of samples collected for toxicity testing .....	4
Table 3	Analysis of acute toxicity and Zn concentration in effluent sample collected 8/28/2016 .....	5

## **1.0 SUMMARY AND CONCLUSIONS**

The screening test conducted on sample collected on July 27, 2016, did not have sufficient toxicity to justify further follow up testing. Based on previous analyses measured copper (Cu) and zinc (Zn) concentrations in this sample were sufficient to have caused sub-lethal toxicity. This result suggests that water-effects ratios (WERs) of approximately 3.9 and 9.5 for Cu and Zn, respectively, would be necessary for toxicity on the sample collected on June 7, 2016 to have been caused by Cu and/or Zn. FTN Associates, Ltd. (FTN)'s experience indicates that WERs of this magnitude are common for Cu but not for Zn. Follow-up testing on sample collected August 28-29, 2016, indicated that the measured Zn concentration accounted for only 10% of the observed toxicity.

Results from tests conducted during the third quarter indicate that observed episodes of toxicity since the implementation of this TRE study are most likely not due to Zn.

## **2.0 INTRODUCTION**

The Searcy Wastewater Treatment Plant (SWWTP), in Searcy, Arkansas, has implemented a toxicity reduction evaluation (TRE) study per requirements of National Pollutant Discharge Elimination System (NPDES) Permit No. AR0021601. The TRE is being conducted according to the TRE Action Plan submitted to the Arkansas Department of Environmental Quality (ADEQ) on December 9, 2015, and approved by ADEQ on December 10, 2015. This document provides the results of TRE activities performed during the first quarter of 2016.

## **3.0 TRE ACTIVITIES**

### **3.1 Routine Biomonitoring and Effluent Screening**

Results of quarterly biomonitoring WET testing and effluent screening tests conducted during January 2106 through September 2106 are provided in Table 1. Routine water chemistry

(pH, alkalinity, hardness, conductivity, total ammonia) from each sample is provided in Table 2. No toxicity to *P. promelas* has been observed.

The screening test conducted on sample collected on July 27, 2016 did not have sufficient toxicity to justify further follow up testing. Based on previous analyses measured Cu and Zn concentrations in this sample (Table 1) were sufficient to have caused sub-lethal toxicity. This result suggests that WERs of approximately 3.9 and 9.5 for Cu and Zn, respectively, would be necessary for toxicity on the sample collected on June 7, 2016, to have been caused by Cu and/or Zn. FTN experience indicates that a WERs for Cu of this magnitude are common but not for Zn.

Table 1. Summary of chronic toxicity tests using *C. dubia* conducted on Outfall 001 samples collected during 2016.

% Effluent	Percent Survival (N = 10) on Sampling Date					
	2/23/2016 <sup>1</sup>	3/29/2016	5/23/2016	6/7/2016	7/27/2016	8/28/2016
	3/1/2016 <sup>2</sup>	3/30/2016	5/27/2016	6/8/2016		9/3/2016
Control	90	100	100	100	100	100
8	90		100			100
11	100		100			100
14	100		90			80
19	100	100	100	70	100	90
25	100		100			40*
100		100		40*	100	
% Effluent	Mean Number of Neonates per Female					
	2/23/2016 <sup>1</sup>	3/29/2016	5/23/2016	6/7/2016		
	3/1/2016 <sup>2</sup>	3/30/2016	5/27/2016	6/8/2016		
Control	20.0	19.3	23.9	27.2	28.1	26.3
8	19.3		27.7			15.0*
11	22.4		26.1			14.0*
14	23.5		26.4			10.0*
19	24.3	18.8	27.5	16.3*	30.3	12.7*
25	26.0		27.0			
100		23.7		--	32.9	

<sup>1</sup>First day of sampling period; <sup>2</sup>Last day of sampling period; \*Statistically less than the control(P<0.05).

Table 2. Routine water chemistry of samples collected for toxicity testing.

Parameter	2/23/2016 <sup>1</sup>	3/29/2016	5/23/2016	6/7/2016	7/27/2016	8/28/2016	
	3/1/2016 <sup>2</sup>	3/30/2016	5/27/2016	6/8/2016	7/27/2016	9/3/2016	
pH (su)	7.4	7.1	6.2	6.9	7.5	6.8	
	7.5		7.2			7.8	
	7.6		7.8			8.0	
Average pH	7.5	7.1	7.1	6.9	7.5	7.5	
Alkalinity (mg/L as CaCO <sub>3</sub> )	50	43	9	40	41	31	
	56		48			52	
	64		40			67	
Average alkalinity	56.7	43.0	32.4	40.0	41.0	50.0	
Hardness (mg/L as CaCO <sub>3</sub> )	46	38	65	49	44	50	
	46		58			43	
	45		42			120	
Average hardness	45.7	38.0	55.0	49.0	44.0	71.0	
Conductivity (µS/cm)	260	280	480	290	350	240	
	260		460			260	
	280		280			300	
Average conductivity	266.7	280.0	406.7	290.0	350.0	266.7	
Total ammonia (mg N/L)	5.4	0.4	9.2	2.3	1.7	2.6	
	6.8		9.2			0.4	
	11.0		1.8			2.0	
Average ammonia	7.7	0.4	6.7	2.3	1.7	1.7	
Copper (µg/L)	Total	NM	NM	NM	5.7	7.3	NM
	Dissolved	NM	NM	NM	NM	NM	NM
Zinc (µg/L)	Total	NM	NM	NM	41	99	22*
	Dissolved	NM	NM	NM	NM	NM	20*

<sup>1</sup> - First day of sampling period; <sup>2</sup> - Last day of sampling period; NM - not measured; Measured on sample collected 8/28/2016

#### 4.0 FOLLOW UP TESTING

The biomonitoring test conducted on a sample collected August 28 - September 3, 2016, showed sufficient toxicity to *C. dubia* to justify follow-up TIE testing. However, due to laboratory miscommunication, only minimal follow-up testing was performed on this sample. August 28-29 was tested for acute toxicity and analyzed for total and dissolved Zn (Table 3). A comparison of the measured Zn concentration and observed toxicity on the sample collected

August 28-29, 2016 (Table 3) indicated that the measured Zn concentration accounted for only 10% of the observed toxicity.

Results from these tests indicate that observed episodes of toxicity since the implementation of this TRE study are most likely not due to Zn.

Table 3. Analysis of acute toxicity and Zn concentration in effluent sample collected 8/28/2016.

% sample		48 h results	Hardness slopes	
		% survival	Cu	0.9422
Control		100	Zn	0.8473
6.25		100	LC50 Tus (ug/L) @ hds = 50	
12.5		100	Cu	11.2
25		90	Zn	174
50		70		
100		60		
Effluent values	Hardness (mg/L as CaCO <sub>3</sub> )	50		
	Cu	NM		
	Zn	22		
	Cu	NA		
Hardness Corrected (Hardness = 50)	Cu	NM		
	Zn	23.8		
Predicted toxic units				
	Zn	0.1		

NM - not measured; NA - not applicable

## 5.0 LITERATURE CITED

USEPA. 1992. *Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I* [EPA/600/6-91/005F]. T.J. Norberg-King, D.I. Mount, J.R. Amato, D.A. Jensen and J.A. Thompson, ASci Corp, Duluth, MN.