

August 1, 2011

Daniel K. Dawson Searcy Board of Public Utilities Searcy WWTP P.O. Box 1319 Searcy, AR 72145

RE: NPDES Permit No. AR0021601, AFIN 73-00055

Dear Mr. Dawson:

A review of the NPDES file for the Searcy WWTP for the monitoring period of May 1, 2011 thru May 31, 2011 reveals the following compliance issues:

The facility reported 4 violations of Part I, Section A. of NPDES Permit No.: AR0021601. The effluent violations reported on the DMRs are as follows:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
05/31/11	001A	Solids, total suspended (MO AVG, lb/d)	883	834
05/31/11	001A	Nitrogen, ammonia total (as N) (MO AVG, lb/d)	223.62	208.5
05/31/11	001A	Nitrogen, ammonia total (as N) (7 DA AVG, mg/L)	9.3	7.5
05/31/11	001A	Coliform, fecal general (7 DA GEO, #100mL)	643	400

The Department expects the Searcy WWPT to continue to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at <a href="mailto:anderson@adeq.state.ar.us">anderson@adeq.state.ar.us</a>.

Sincerely,

Alan Anderson Enforcement Analyst

Water Division / Enforcement Branch

lan anders