

ADEQ

ARKANSAS
Department of Environmental Quality

July 25, 2016

Daniel Dawson, Manager
Searcy Wastewater Treatment Facility
P.O. Box 1319
Searcy, AR 72145

RE: NPDES Permit Number AR0021601, AFIN 73-00055, Permit Violations

Dear Mr. Dawson:

A review of the NPDES file for the above referenced facility shows that the following violations of the permitted effluent limits have been reported since 06/01/14:

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
05/31/2016	001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	7.5	8.4	12%
04/30/2015	001-A	Coliform, fecal, colony forming units, 7 DA GEO, #/100mL	400	506	27%
06/30/2014	001-A	Coliform, fecal, colony forming units, 7 DA GEO, #/100mL	400	876	119%

Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, please be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Should you have any questions, feel free to contact me at 501-682-0635 or e-mail anderson@adeq.state.ar.us.

Sincerely,



Alan Anderson
Enforcement Analyst
Office of Water Quality