

BOARD MEMBERS
Ronnie McFarland
Mel Sansom
Steve Lightle
Donnie Miller
Reynie Rutledge



GENERAL MANAGER
Daniel K. Dawson

ASSISTANT GENERAL
MANAGER
Tim W. Cleveland

July 25, 2022

Arkansas Department of Environmental Quality

Enforcement Branch, Office of Water Quality

5301 Northshore Drive

North Little Rock, AR 72118-5317

Discharge Permit # AR0021601

To whom it may concern, this letter is to represent the Final Compliance report of the changes that were made to our Wastewater Discharge Permit on May 1, 2019.

Those changes are pertaining to the TRC Limit of .056 mg/l, and the changes to the WET Testing of the Ceriodaphnia dubia (Chronic), Lethality: Not <20%, Sub-Lethality: Not <20%.

Both of these have been in compliance with the permit since it was issued.

Thank you,

A handwritten signature in black ink, appearing to read "Jimmy Smith", written over a white background.

Jimmy Smith

Manager WWTP

Searcy Water Utilites