

BOARD MEMBERS
Ronnie McFarland
Mel Sansom
Steve Lightle
Donnie Miller
Reynie Rutledge



GENERAL MANAGER
Daniel K. Dawson

ASSISTANT GENERAL
MANAGER
Tim W. Cleveland

June 18, 2018

Sent via NetDMR

NPDES Enforcement Division
A.D.E.Q.
5301 Northshore Dr.
North Little Rock, AR 72118-5317

Re: Searcy Wastewater Treatment Plant
NPDES Permit No. AR0021601
AFIN No. 73-00055

To Whom It May Concern:

We regret to report that there is an excursion noted in the Ammonia Nitrogen 7-day average reported in this DMR for the month ending 05/31/16. We think this was due to unexpectedly high ammonia levels in return flows coming from the equalization pond. The situation has returned to normal and is resolved.

If you have any questions, please feel free to contact me.

Sincerely,

SEARCY WATER UTILITIES

A handwritten signature in black ink, appearing to read "D. Dawson", is written over a horizontal line. Below the signature, the name "Daniel K. Dawson" and title "General Manager" are printed.

Daniel K. Dawson
General Manager

Enclosures