

**BOARD MEMBERS**

Ronnie McFarland  
Steve Lightle  
Donnie Miller  
Reynie Rutledge  
Butch Gardner



**GENERAL MANAGER**

Daniel K Dawson

**ASSISTANT GENERAL  
MANGER**

Scott Boggs

---

March 23, 2021

Sent via NetDMR

NPDES Enforcement Division  
A.D.E.Q.  
5301 Northshore Dr.  
North Little Rock, AR 72118-5317

Re: Searcy Wastewater Treatment Plant  
NPDES Permit No. AR0021601  
AFIN No. 73-00055

To Whom It May Concern:

We regret to report that there is an excursion noted in the pH parameter reported in this DMR for the month ending 02/28/21. Our investigation of this event has revealed that this was due to unusually low water temperatures due to the unusual winter weather and also having to use much higher than normal chlorine to maintain disinfection. The situation has returned to normal and is resolved.

If you have any questions, please feel free to contact me.

Sincerely,

SEARCY WATER UTILITIES

A handwritten signature in black ink, appearing to read "D. Dawson", is written over a horizontal line.

Daniel K. Dawson  
General Manager

Enclosures