

Monthly Overflow Report

In accordance with Part III (4) of NPDES Permit No. AR0021601

DMR Period: From: To:
 1/1/2013 1/31/213


<u>Overflow #</u>	<u>Date</u>	<u>Time</u>	<u>Duration</u>	<u>Location</u>	<u>Est. Volume</u>	<u>Cause</u>	<u>Env. Impact</u>	<u>Action Taken</u>	<u>Discharge</u>
1	1/20/2013	3:19 PM	71 min.	E. Race & Blakeney	60	grease	neah	Jetted line	not reach stream
2	1/26/2013	1:30 PM	3 hrs.	206 S. Gum	100	grease	neah	Jetted line	not reach stream

Certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possiblity of fine and imprisonment for knowing violations.

Report submitted by:

Date signed:



Daniel K. Dawson, General Manager

February 12, 2013

Certified Mail, Return Receipt Requested: 7009 0820 0002 0865 0485

CERTIFIED MAIL™

SEARCY WATER UTILITIES

300 NORTH ELM STREET

P.O. BOX 1319

SEARCY, ARKANSAS 72145-1319




7009 0820 0002 0865 0485



UNITED STATES
POSTAL SERVICE

1000



72118

U.S. POSTAGE
PAID
SEARCY, AR.
72143
FEB 12, 13
AMOUNT

\$6.31

00051413-05

**RETURN RECEIPT
REQUESTED**

NPDES Enforcement Division

A.D.E.Q.

5301 Northshore Dr.

North Little Rock, AR 72118-5317

721185317 RC15

