

Monthly Overflow Report

In accordance with Part III (4) of NPDES Permit No. AR0021601

DMR Period: From: To:
 11/1/2012 11/30/2012

<u>Overflow #</u>	<u>Date</u>	<u>Time</u>	<u>Duration</u>	<u>Location</u>	<u>Est. Volume</u>	<u>Cause</u>	<u>Env. Impact</u>	<u>Action Taken</u>	<u>Discharge</u>
1	11/25/2012	11:30 AM	30 min.	#20 Meadow Ln.	30	debris	neah	Jetted line	not reach stream

Certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Report submitted by:



Daniel K. Dawson, General Manager

Date signed:

December 17, 2012

Certified Mail, Return Receipt Requested: 7009 0820 0002 0865 0454

SEARCY WATER UTILITIES

300 NORTH ELM STREET

P.O. BOX 1319

SEARCY, ARKANSAS 72145-1319

CERTIFIED MAIL™



7009 0820 0002 0865 0454


CPU U.S. POSTAGE

\$ 6.15⁰

PB 1P 000
3661135
FCML

MAILED

DEC 17 2012
72143



NPDES Enforcement Division
A.D.E.Q.
5301 Northshore Dr.
North Little Rock, AR 72118-5317