


BOARD MEMBERS
Roger Vaughan
Mel Sansom
Steve Lightle
Donnie Miller
Reynie Rutledge



GENERAL MANAGER
Daniel K. Dawson

ASSISTANT GENERAL
MANAGER
Tim W. Cleveland

June 20, 2012

CERTIFIED MAIL, Return Receipt Requested: 7009 0820 0002 0865 0362

NPDES Enforcement Division
A.D.E.Q.
5301 Northshore Dr.
North Little Rock, AR 72118-5317

Re: Searcy Wastewater Treatment Plant
NPDES Permit No. AR0021601
AFIN No. 73-00055

To Whom It May Concern:

Enclosed you will please find a discharge monitoring report (DMR) for the monthly monitoring period ending May 31, 2012.

We regret to report that we have an excursion as noted on this DMR in the Ammonia Nitrogen concentration parameter that was caused by a temporary shut-down of the belt press for maintenance. We have had the belt press shut down before without any ill-effect to treatment, so it is unknown why this shut-down caused a problem.

We are glad to say that the system has returned to normal and we do not anticipate any more such violations.

If you have any questions, please feel free to contact me.

Sincerely,

SEARCY WATER UTILITIES

A handwritten signature in black ink, appearing to read "Dan Dawson", is written over a horizontal dashed line.

Daniel K. Dawson
General Manager

Enclosures

SEARCY WATER AND SEWER SYSTEM

300 NORTH ELM STREET

P.O. BOX 1319

SEARCY, ARKANSAS 72145-1319


CERTIFIED MAIL™



7009 0820 0002 0865 0362



1000



72118

U.S. POSTAGE
PAID
SEARCY, AR
72143
JUN 20, 12
AMOUNT

\$5.95
00023179-09

**RETURN RECEIPT
REQUESTED**

NPDES Enforcement Division
A.D.E.Q.
5301 Northshore Dr.
North Little Rock, AR 72118-5317

721185317 R015

