

Monthly Overflow Report

In accordance with Part III (4) of NPDES Permit No. AR0021601


DMR Period: From: To:
 7/1/2012 7/31/2012

<u>Overflow #</u>	<u>Date</u>	<u>Time</u>	<u>Duration</u>	<u>Location</u>	<u>Est. Volume</u>	<u>Cause</u>	<u>Env. Impact</u>	<u>Action Taken</u>	<u>Discharge</u>
1	7/25/2012	2:50 PM	55 min.	1703 E. Market	500	debris	neah	Jetted line	Deener Crk.

Certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Report submitted by:



Daniel K. Dawson, General Manager

Date signed:

August 13, 2012

Certified Mail, Return Receipt Requested: 7009 0820 0002 0865 0416

CERTIFIED MAIL™


SEARCY WATER UTILITIES
300 NORTH ELM STREET
P.O. BOX 1319
SEARCY, ARKANSAS 72145-1319



7009 0820 0002 0865 0416



1000



72118

U.S. POSTAGE
PAID
SEARCY, AR
72143
AUG 14, 12
AMOUNT

\$5.95
00023179-09

**RETURN RECEIPT
REQUESTED**

NPDES Enforcement Division
A.D.E.Q.
5301 Northshore Dr.
North Little Rock, AR 72118-5317