

Monthly Overflow Report
In accordance with Part III (4) of NPDES Permit No. AR0021601

DMR Period: From: 5/1/2013 To: 5/31/2013


108817
JUN 17 2013
1 20 50 PM '13

<u>Overflow #</u>	<u>Date</u>	<u>Time</u>	<u>Duration</u>	<u>Location</u>	<u>Est. Volume</u>	<u>Cause</u>	<u>Env. Impact</u>	<u>Action Taken</u>	<u>Discharge</u>
1	5/9/2013	3:05 PM	25 min	1302 Fox Dr.	20	debris	neah	Jetted line	not reach stream
2	5/14/2013	9:15 AM	20 min	6 Willowood	30	roots, gr.	neah	Jetted line	not reach stream

Certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Report submitted by:


Daniel K. Dawson, General Manager

Date signed:

June 17, 2013