

Monthly Overflow Report
In accordance with Part III (4) of NPDES Permit No. AR0021601

DMR Period: From: To:
 12/1/2012 12/31/2012


<u>Overflow #</u>	<u>Date</u>	<u>Time</u>	<u>Duration</u>	<u>Location</u>	<u>Est. Volume</u>	<u>Cause</u>	<u>Env. Impact</u>	<u>Action Taken</u>	<u>Discharge</u>
1	12/21/2012	9:30 PM	42 min.	W. Arch & Olive	50	grease	neah	Jetted line	not reach stream

Certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Report submitted by:

Date signed:



Daniel K. Dawson, General Manager

January 15, 2013.

Certified Mail, Return Receipt Requested: 7009 0820 0002 0865 0461

CERTIFIED MAIL™

SEARCY WATER UTILITIES

300 NORTH ELM STREET

P.O. BOX 1319


SEARCY, ARKANSAS 72145-1319



7009 0820 0002 0865 0461



UNITED STATES
POSTAL SERVICE



1000

72118

U.S. POSTAGE
PAID
SEARCY, AR
72143
JAN 15, 13
AMOUNT

\$5.95

00051413-05

**RETURN RECEIPT
REQUESTED**

NPDES Enforcement Division
A.D.E.Q.
5301 Northshore Dr.
North Little Rock, AR 72118-5317

721185317 R015

