

ADEQ

ARKANSAS
Department of Environmental Quality

August 5, 2011

Cabot Water & Wastewater Commission
Attention: Tim Joyner
76 Marshall Lane
Cabot, AR 72023

RE: NPDES Permit Number AR0021661, AFIN 43-00059

Dear Mr. Joyner:

A recent review of the NPDES file for **Cabot Water & Wastewater Commission** has revealed the following violations for the monitoring period ending **06/30/2011**.

DISCHARGE NUMBER	PARAMETER	VIOLATION	LIMIT	UNITS
001-A	NH3-N	2.7	2.1 Mo Avg.	mg/L
001-A	NH3-N	6.0	5.2 7 Day Avg.	mg/L

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit require you to take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Please refer to NPDES Permit Number **AR0021661** and AFIN **43-00059** in any written correspondence to ADEQ. Should you have any questions, feel free to call 501-682-0631 or e-mail meints@adeq.state.ar.us.

Sincerely,



René E. Meints
Enforcement Analyst
Water Division Enforcement Branch