

ADEQ

ARKANSAS
Department of Environmental Quality

September 5, 2018

Tim Joyner, General Manager
Cabot Water and WW Commission
P.O. Box 1287
Cabot, AR 72023

RE: NPDES Permit Number AR0021661, AFIN 43-00059
Permitted Effluent Limitation Violations

Dear Mr. Joyner,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility for the reveals the following compliance issues:

The facility has reported 2 violations of Part I, Section A of NPDES Permit No. AR0021661 during the review period. A detailed list of the violations has been included with this letter. The Department expects that the Cabot Water and WW Commission to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at gavin.gray@adeq.state.ar.us.

Sincerely,



Gavin Gray
Enforcement Analyst
Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
07/31/2018	001-A	Nitrogen, ammonia total [as N], MO AVG, mg/L	2.1	3.4	62%
07/31/2018	001-A	Nitrogen, ammonia total [as N], 7 DA AVG, mg/L	5.2	6.8	31%

