

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

**RE: NPDES Permit No:** AR0021661

**Discharge Number:** A-001-Monthly

**Facility:** Cabot Water & Wastewater Treatment Facility

**Address** 76 Marshall Lane

**City:** Cabot

**State:** AR

**Zip:** 72023

**Contact:** Tim Joyner

**Phone:** 501-605-1740

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
March, 2022	DO		6.4 mg/L	6.5 mg/L Inst. Minimum

We feel this problem was due to:

**Cabot received 4.8" of rainfall on March 22, the day the low DO occurred.**

We plan on correcting the problem in this manner:

**We will monitor DO during heavy rain events**


Time estimated that it will take to correct the problem/s:

**Problem was corrected after storm event subsided.**

Sincerely,



Authorized Signature



Date