


NON-COMPLIANCE REPORT

Permit Number: AR0021661

Facility Name: CABOT WATERWORKS

Month / Year: FEBRUARY, 2013

Authorized Signature: 

Type of Violation (Avg/Max., Bypass Overflow, Etc.)	Permit Limit	Date of Violation	Duration of Violation	Cause of Violation	Corrective Action or Other Narrative
Ammonia, Monthly Avg	4	2/4/2013	2-3 wks	SUSPECT LOW WATER TEMP.	NO WASTING
Ammonia, 7-day Avg	6	2/4/2013	2-3 wks	SUSPECT LOW WATER TEMP.	NO WASTING

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319 (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

CABOT WATERWORKS
P.O. BOX 1287
CABOT, AR 72023

LITTLE ROCK AR 722

12 MAR 2013 PM 4 1



Enforcement Section
ADEQ
5301 North Shore Drive
North Little Rock, AR 72118-5317

DMR ENCLOSED

72118531799

