

# NON-COMPLIANCE NOTIFICATION

DMR Monitoring Period 4/01/2016 - 4/30/2016

**FROM:** Cabot Wastewater Treatment Facility      **DATE:** 5/9/2016  
76 Marshall Lane  
Cabot, AR 72023

**PERMIT #:** AR0021661

**TO:** NPDES Enforcement  
ADEQ  
5301 Northshore Drive  
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Dissolved Oxygen was barely below the Instant MIN permit limit of 6.5 mg/L

3. CAUSE FOR NON-COMPLIANCE:


4. DURATION OF NON-COMPLIANCE:

The Dissolved Oxygen was recorded below the limit on April 5th, 2016.

5. CORRECTIVE ACTION BEING TAKEN:

*Monitor*

SIGNATURE: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'JJ', written over a horizontal line.

# WaterWorks **CABOT**

One City Plaza, Suite B  
P.O. Box 1287  
Cabot, Arkansas 72023

LITTLE ROCK AR 722

10 MAY 2005 PM 2 L



Arkansas Department of Environmental Quality  
NPDES Branch, Water Division  
5301 Northshore Drive  
Little Rock, Arkansas 72118

72118-591799

