

NON-COMPLIANCE REPORT

Permit Number: AR0021661

Facility Name: CABOT WATERWORKS

Month / Year: JUNE, 2013

Authorized Signature: 

Type of Violation (Avg/Max., Bypass Overflow, Etc.)	Permit Limit	Date of Violation	Duration of Violation	Cause of Violation	Corrective Action or Other Narrative
Ammonia, mg/L 7 day avg	5.2	5/28/2013	4 days	draining EQ basin	closed valve, stopped draining EQ basin
Ammonia, mg/L monthly avg	2.1	5/28/2013	4 days	draining EQ basin	closed valve, stopped draining EQ basin
Ammonia, mg/L 7 day avg	5.2	6/17/2013	5 days	draining EQ basin	closed valve, stopped draining EQ basin
Ammonia, mg/L monthly avg	2.1	6/17/2013	5 days	draining EQ basin	closed valve, stopped draining EQ basin

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. 1001 AND 33 U.S.C. 1319 (Penalties under these statues may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

Cabot WaterWorks  
P.O. Box 1287  
Cabot, AR 72023

LITTLE ROCK AR 722

15 FEB 2013 PM 3:1



ADEQ  
Enforcement Section  
5301 Northshore Dr.  
North Little Rock, AR 72118

**DMR ENCLOSED**

72118532801

