

NON-COMPLIANCE NOTIFICATION

FROM: Cabot Water Wastewater
P.O. Box 1287
Cabot, Ar.
72023

DATE: 6-6-2012

PERMIT NO. AR0021661

TO: NPDES Enforcement
ADEQ
5301 Northshore Dr.
N. Little Rock, Ar. 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION: expressed in mg/l.

Monthly average on ammonia is 4.4 with maximum of 2.1; 2.3 above.
7 day average on ammonia is 8.1 with maximum of 5.2; 2.9 above.

3. CAUSE FOR NON-COMPLIANCE:

HIGH LOADING

4. DURATION OF NON-COMPLIANCE:

MAY 14 - 24TH, 2012

5. CORRECTIVE ACTION BEING TAKEN:

INCREASE WASTING, INCREASE INSPECTIONS OF
GREASE TRAPS & OIL SEPARATORS

SIGNATURE: _____

