

## NON-COMPLIANCE NOTIFICATION

**FROM:** Cabot Wastewater Treatment Facility  
76 Marshall Lane  
Cabot, AR 72023

**DATE:** 10/9/2015

**PERMIT #:** AR0021661

**TO:** NPDES Enforcement  
ADEQ  
5301 Northshore Drive  
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Ammonia exceeded the maximum value on the 7 day average reporting limits.

3. CAUSE FOR NON-COMPLIANCE:

*WE SUSPECT ALGAE GROWTH IN AERATION BASIN  
RESULTING IN LOW DISSOLVED OXYGEN.*

4. DURATION OF NON-COMPLIANCE:

The non compliance violations took place from September 22nd-September 30th.

5. CORRECTIVE ACTION BEING TAKEN:

SIGNATURE: \_\_\_\_\_

A large, stylized handwritten signature in black ink, consisting of several loops and a long horizontal stroke at the end, positioned over a solid horizontal line.

# CWaterWorks CABOT

One City Plaza, Suite B  
P.O. Box 1287  
Cabot, Arkansas 72023



Enforcement Section  
ADEQ  
5301 North Shore Drive  
North Little Rock, AR 72118-5317

**DMR ENCLOSED**