

NON-COMPLIANCE NOTIFICATION

FROM: Cabot Wastewater Treatment Facility
76 Marshall Lane
Cabot, AR 72023

DATE: 11/13/2015

PERMIT #: AR0021661

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Ammonia exceeded the maximum value on the 7 day average reporting limits.

3. CAUSE FOR NON-COMPLIANCE:

DRAINING EXCESS WATER FROM EQ BASIN

4. DURATION OF NON-COMPLIANCE:

The non compliance violations took place between Septemver 28th-October 2nd.

5. CORRECTIVE ACTION BEING TAKEN:


SLOW DRAINING RATE

SIGNATURE: _____

A handwritten signature in black ink, consisting of a large, stylized initial 'D' followed by a horizontal line and a flourish.

CWaterWorks CABOT

One City Plaza, Suite B
P.O. Box 1287
Cabot, Arkansas 72023



Enforcement Section
ADEQ
5301 North Shore Drive
North Little Rock, AR 72118-5317

DMR ENCLOSED

