43-00059

Sanitary Sewer Overflow Monthly Report

Facility Name: Cabot Wastewater **Permit Number:** AR0021661 **Reporting Period (Month/Year):** September, 2012

☐ No Sanitary Sewer Overflows This Monitoring Period

POST MARKED OCT 25 2012

Summary Report Code Descriptions			
Cause(s) of SSO	**SSO Impact**	**Action(s) Taken**	**Ultimate Discharge Location**
CO-Construction	NEAH - No Evidence of Adverse Health or Environmental Impact	VAC- Vacuumed	CR-Creek/Stream/River (please specify)
R-Rainfall		WO-Work Order	CH-Contained in Hole
E-Equipment Failure		DD-Disinfect/Deodorize	CB-Contained in Building
LF-Line Failure	OEHC - Observed or Evidence of Human Contact	EC-Environmental Cleanup	OJ-Ditch
D-Debris		HC-Hydro Cleaned	DR-Drop Inlet
RO-Roots		L-Limed	PA-Pavement
G-Grease	EFK - Evidence of Fish Kill	HR-Hand Rodded	GR-Ground Surface
V-Vandalism		EN-Referred to Engineering	
		PN-Public Notification	

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in Gallons)	Cause of SSO	Environmental Impact	Action(s) Taken to Address SSO	Ultimate Discharge Location
15 Rockwood	2426	9/13/2012	9/13/2012	500	G-Grease	NEAH	Wk-Order/Lime	GR-GROUND
13 Sun Vista Ln	2418	9/23/2012	9/23/2012	1000	G	NEAH	HC/L	GR/OJ

Signature of Cognizant or Ranking Official

Date 10/25/12

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly, gather and evaluate the information submitted. Based on my inquiry of the persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."