

**CONFIRMATION NUMBER**

**1066E072-9AD1-45E6-8F93-43E65701C3EF**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 1066E072-9AD1-45E6-8F93-43E65701C3EF

**Date Sent:** 12/3/2014

SSO  Bypass  Upset

Facility Permit Number: **AR000021750**

Facility name:

**Massard WWTP**

Date Overflow Began: **12/2/2014**

Time:

**6:39 pm**

Date Overflow Ended: **12/2/2014**

Time:

**10:30 pm**

Location: **4619 South Q Street S003-1666 to 1665 Cleanout overflow**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:** **171**

(Give an estimate in gallons)

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Disinfected and Deodorized
- Jet-Vac
- Hydro Cleaned
- Hand rodded
- Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment
- Public Notification
- Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Supt**

Telephone Number **(479) 784-2331**

Additional Comments if Needed:

**CONFIRMATION NUMBER**

**20184798-7282-4EDA-BE6C-C2B52E4F6F43**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 20184798-7282-4EDA-BE6C-C2B52E4F6F43  
**Date Sent:** 12/12/2014

SSO  Bypass  Upset

Facility Permit Number:	<b>AR0021750</b>	Facility name:	<b>Massard WWTP</b>
Date Overflow Began:	<b>12/12/2014</b>	Time:	<b>10:28 am</b>
Date Overflow Ended:	<b>12/12/2014</b>	Time:	<b>12:30 pm</b>
Location:	<b>3008 Glen Flora Way Z004-0930 to 0934</b>		

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:** **92**

(Give an estimate in gallons)

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd** Title **Supt.** Telephone Number **(479) 784-2331**

Additional Comments if Needed: cleanup scheduled

**CONFIRMATION NUMBER**

**C7257BAF-3D54-40D5-8A77-5476C3E14DC5**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** C7257BAF-3D54-40D5-8A77-5476C3E14DC5

**Date Sent:** 12/15/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0021750**

Facility name:

**Massard WWTP**

Date Overflow Began: **12/14/2014**

Time:

**4:06 pm**

Date Overflow Ended: **12/14/2014**

Time:

**4:39 pm**

Location:

**3404 North 47th St.  
S009 - 0920 to 0910  
Cleanout overflow**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:** **66**

(Give an estimate in gallons)

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Superintendent**

Telephone Number **(479) 784-2331**

Additional Comments if Needed: cleanup scheduled

**CONFIRMATION NUMBER**

**8123740A-4466-4438-A2B3-DB8CDDDB1B63B**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 8123740A-4466-4438-A2B3-DB8CDDDB1B63B

**Date Sent:** 12/15/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0021750**

Facility name:

**Massard WWTP**

Date Overflow Began: **12/14/2014**

Time:

**2:00 pm**

Date Overflow Ended: **12/14/2014**

Time:

**3:47 pm**

Location: **4619 South Q St. S003 - 1660 to 1650  
Cleanout overflow on service line**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:** **107**

*(Give an estimate in gallons)*

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Disinfected and Deodorized
- Jet-Vac
- Hydro Cleaned
- Hand rodded
- Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment
- Public Notification
- Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Supt.**

Telephone Number **(479) 784-2331**

Additional Comments if Needed: cleanup scheduled

**CONFIRMATION NUMBER**

**B4602A58-A2CA-4C7B-99A9-ABFB121ABDDD**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** B4602A58-A2CA-4C7B-99A9-ABFB121ABDDD

**Date Sent:** 12/14/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**  
Date Overflow Began: **12/13/2014**  
Date Overflow Ended: **12/14/2014**

Facility name: **P Street WWTP**  
Time: **11:30 pm**  
Time: **12:47 am**

Location: **3630 Barry Ave P007 - 0640 to 0630  
Service line clean out.**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Volume:** **77**

*(Give an estimate in gallons)*

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Disinfected and Deodorized
- Jet-Vac
- Hydro Cleaned
- Hand rodded
- Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment
- Public Notification
- Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd** Title **Supt.** Telephone Number **(479) 784-2331**

Additional Comments if Needed: **Cleanup scheduled.**

CONFIRMATION NUMBER

DA2DC601-CC3A-4193-BADE-74EBA2AEDE1

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

Close this window Print this page

24-Hour Sanitary Sewer Overflow Report

SSO ID#: DA2DC601-CC3A-4193-BADE-74EBA2AEDE1

Date Sent: 12/15/2014

SSO Bypass Upset

Facility Permit Number: AR0033278

Facility name:

P Street WWTP

Date Overflow Began: 12/15/2014

Time:

2:10 pm

Date Overflow Ended: 12/15/2014

Time:

3:20 pm

Location: 2501 Glen Flora Way
2005-0550
Manhole Overflow into Storm Drain

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- (X) Manhole Overflow
(L) Lift Station Overflow
(L) Main Line Overflow
(L) Service Line Overflow
(L) Other Overflow Type:

(Enter overflow type if not listed)

Volume: 1750

(Give an estimate in gallons)

Impact of SSO Event: SSO Reached Receiving Water (river,stream)

Cause of Overflow

- (L) I & I - Rainfall
(X) Roots
(L) Grease
(L) Debris
(L) Equipment Failure
(L) Construction
(L) Vandalism
(L) Power Failure
(L) Line Failure/Break
(L) Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- (X) Machine rodded (X) Disinfected and Deodorized
(L) Jet-Vac (L) Hydro Cleaned
(L) Hand rodded (L) Spread Lime on Affected Area
(L) Used Generator To Power Pumps/Equipment (L) Public Notification
(L) Other: Describe

Environmental Damage

- (L) OEHC - Observed or Evidence of Human Contact (X) NEAH - No Evidence of Adverse Health/Environmental Impact
(L) OEEI - Observed or Evidence of Environmental Impact (L) EFK - Evidence of Fish Kill

Reported By Steve Floyd

Title Supt.

Telephone Number (479) 784-2331

Additional Comments: clean up scheduled

**CONFIRMATION NUMBER**

**3AEF3EB3-85EC-46FD-A351-4D8F66EF4D7F**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 3AEF3EB3-85EC-46FD-A351-4D8F66EF4D7F

**Date Sent:** 12/17/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street WWTP**

Date Overflow Began: **12/16/2014**

Time:

**3:15 pm**

Date Overflow Ended: **12/16/2014**

Time:

**6:00 pm**

Location: **2408 South Houston St.  
MC05 - 2280  
Line failure**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:** **3125**

(Give an estimate in gallons)

**Impact of SSO Event:** **SSO Reached Public Land Only (ground)**

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Supt.**

Telephone Number **(479) 784-2331**

Additional Comments if Needed: **Line repair scheduled.**

**CONFIRMATION NUMBER**

**1FD25696-C828-4465-A580-D3D0BE16D2DC**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 1FD25696-C828-4465-A580-D3D0BE16D2DC

**Date Sent:** 12/18/2014

SSO  Bypass  Upset

Facility Permit Number:	<b>AR0021750</b>	Facility name:	<b>Massard WWTP</b>
Date Overflow Began:	<b>12/17/2014</b>	Time:	<b>9:30 pm</b>
Date Overflow Ended:	<b>12/17/2014</b>	Time:	<b>10:20 pm</b>

Location: **2115 North 47th Terrace  
Backup into building.  
S008-0460 to 0480**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **building**

(Enter overflow type if not listed)

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:** **500**

(Give an estimate in gallons)

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- |  |   |
|--|---|
| <input type="checkbox"/> Machine rodded                          | <input type="checkbox"/> Disinfected and Deodorized   |
| <input checked="" type="checkbox"/> Jet-Vac                      | <input type="checkbox"/> Hydro Cleaned                |
| <input type="checkbox"/> Hand rodded                             | <input type="checkbox"/> Spread Lime on Affected Area |
| <input type="checkbox"/> Used Generator To Power Pumps/Equipment | <input type="checkbox"/> Public Notification          |
| <input type="checkbox"/> Other: Describe                         |   |

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd** Title **Supt.** Telephone Number **(479) 784-2331**

Additional Comments if Needed:



**CONFIRMATION NUMBER**

**03FD51CA-AAE7-4C4F-9EE5-D12127B815E4**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 03FD51CA-AAE7-4C4F-9EE5-D12127B815E4

**Date Sent:** 12/18/2014

SSO  Bypass  Upset

Facility Permit Number:	<b>AR0033278</b>	Facility name:	<b>P Street WWTP</b>
Date Overflow Began:	<b>12/17/2014</b>	Time:	<b>8:05 pm</b>
Date Overflow Ended:	<b>12/17/2014</b>	Time:	<b>9:15 pm</b>

Location: **104 North 13th Street**  
**P010-0810 to 0820**  
**Main line stoppage caused backup into building.**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **Building backup**  
*(Enter overflow type if not listed)*

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:** **1050**  
*(Give an estimate in gallons)*

**Impact of SSO Event:** **SSO Reached Receiving Water (river,stream)**

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- |  |   |
|--|---|
| <input type="checkbox"/> Machine rodded                          | <input type="checkbox"/> Disinfected and Deodorized   |
| <input checked="" type="checkbox"/> Jet-Vac                      | <input type="checkbox"/> Hydro Cleaned                |
| <input type="checkbox"/> Hand rodded                             | <input type="checkbox"/> Spread Lime on Affected Area |
| <input type="checkbox"/> Used Generator To Power Pumps/Equipment | <input type="checkbox"/> Public Notification          |
| <input type="checkbox"/> Other: Describe                         |   |

**Environmental Damage**

- |  |   |
|--|---|
| <input type="checkbox"/> OEHC - Observed or Evidence of Human Contact        | <input checked="" type="checkbox"/> NEAH - No Evidence of Adverse Health/Environmental Impact |
| <input type="checkbox"/> OEEI - Observed or Evidence of Environmental Impact | <input type="checkbox"/> EFK - Evidence of Fish Kill  |

Reported By **Steve Floyd** Title **Supt.** Telephone Number **(479) 784-2331**

Additional Comments if Needed: **Owner notified.**

**CONFIRMATION NUMBER**

**222ED416-7D09-46B6-B18E-E8BEAFECAD49**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 222ED416-7D09-46B6-B18E-E8BEAFECAD49

**Date Sent:** 12/19/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**  
Date Overflow Began: **12/19/2014**  
Date Overflow Ended: **12/19/2014**

Facility name: **P Street WWTP**  
Time: **3:20 pm**  
Time: **4:20 pm**

Location:

**1118 South 24th St.  
Overflow into Building  
Main line stoppage P006 - 1840 to1830**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **Building overflow**

*(Enter overflow type if not listed)*

**Volume:** **600**

*(Give an estimate in gallons)*

**Impact of SSO Event:** **SSO Reached Receiving Water (river,stream)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd** Title **Supt.** Telephone Number **(479) 784-2331**

Additional Comments if Needed:

**CONFIRMATION NUMBER**

**99F531F2-DBBC-4C62-815A-BOAFD1A5DB5C**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 99F531F2-DBBC-4C62-815A-BOAFD1A5DB5C

**Date Sent:** 12/20/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street WWTP**

Date Overflow Began: **12/20/2014**

Time:

**11:30 am**

Date Overflow Ended: **12/20/2014**

Time:

**1:00 pm**

Location:

**4112 South 16th Street MC06-2100 to 2090**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Volume: 450**

*(Give an estimate in gallons)*

**Impact of SSO Event: SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Disinfected and Deodorized
- Jet-Vac
- Hydro Cleaned
- Hand rodded
- Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment
- Public Notification
- Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd** Title **Supt.** Telephone Number **(479) 784-2331**

Additional Comments if Needed: **Cleanup scheduled**

**CONFIRMATION NUMBER**

**3EF4B49B-4A2A-4E2F-8407-2C16ACC774CD**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 3EF4B49B-4A2A-4E2F-8407-2C16ACC774CD

**Date Sent:** 12/23/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street WWTP**

Date Overflow Began: **12/23/2014**

Time:

**12:25 pm**

Date Overflow Ended: **12/23/2014**

Time:

**1:30 pm**

Location: **3101 Fincastle Drive Z004-0810 to 0800  
Cleanout overflow**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:** **130**

(Give an estimate in gallons)

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Supt.**

Telephone Number **(479) 784-2331**

Additional Comments if Needed: cleanup scheduled

**CONFIRMATION NUMBER**

**1FA6A3B0-D2BF-4F4B-B317-0FD8DBE11C08**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 1FA6A3B0-D2BF-4F4B-B317-0FD8DBE11C08

**Date Sent:** 12/23/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Date Overflow Began: **12/23/2014**

Date Overflow Ended: **12/23/2014**

Location:

Facility name:

Time:

Time:

**P Street WWTP**

**12:45 pm**

**1:45 pm**

**7100 Hwy 271 South  
Main line leak  
CS01-1220 to 0770**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:** **600**

(Give an estimate in gallons)

**Impact of SSO Event:** **SSO Reached Public Land Only (ground)**

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Disinfected and Deodorized
- Jet-Vac
- Hydro Cleaned
- Hand rodded
- Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment
- Public Notification
- Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Supt.**

Telephone Number **(479) 784-2331**

Additional Comments if Needed:



**CONFIRMATION NUMBER**

**601A087F-3DC5-4477-86FB-9087C1AD9FA2**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 601A087F-3DC5-4477-86FB-9087C1AD9FA2

**Date Sent:** 12/23/2014

SSO  Bypass  Upset

Facility Permit Number:	<b>AR0033278</b>	Facility name:	<b>P Street WWTP</b>
Date Overflow Began:	<b>12/23/2014</b>	Time:	<b>8:40 am</b>
Date Overflow Ended:	<b>12/23/2014</b>	Time:	<b>9:15 am</b>

Location: **104 North 13th St. P010-0820 to 0810**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow

Other Overflow Type: **Building**

(Enter overflow type if not listed)

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:** **50**

(Give an estimate in gallons)

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- |  |   |
|--|---|
| <input checked="" type="checkbox"/> Machine rodded               | <input type="checkbox"/> Disinfected and Deodorized   |
| <input type="checkbox"/> Jet-Vac                                 | <input type="checkbox"/> Hydro Cleaned                |
| <input type="checkbox"/> Hand rodded                             | <input type="checkbox"/> Spread Lime on Affected Area |
| <input type="checkbox"/> Used Generator To Power Pumps/Equipment | <input type="checkbox"/> Public Notification          |
| <input type="checkbox"/> Other: Describe                         |   |

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact       NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact       EFK - Evidence of Fish Kill

Reported By **Steve Floyd** Title **Supt.** Telephone Number **(479) 784-2331**

Additional Comments if Needed: ^  
v

**CONFIRMATION NUMBER**

**65D67AB0-6C2A-45ED-9212-E2F76A6F565B**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 65D67AB0-6C2A-45ED-9212-E2F76A6F565B

**Date Sent:** 12/24/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0021750**

Facility name:

**Massard WWTP**

Date Overflow Began: **12/23/2014**

Time:

**8:25 pm**

Date Overflow Ended: **12/23/2014**

Time:

**10:15 pm**

Location:

**4001 Glen Flora Way M003-1910**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Volume:**

**550**

*(Give an estimate in gallons)*

**Impact of SSO Event:**

**SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded  Disinfected and Deodorized
- Jet-Vac  Hydro Cleaned
- Hand rodded  Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment  Public Notification

Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact  NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact  EFK - Evidence of Fish Kill

Reported By **Steve Floyd** Title **Supt.** Telephone Number **(479) 784-2331**

Additional  
Comments  
if Needed:

Cleanup scheduled

**CONFIRMATION NUMBER**

**8BA0EEC8-B929-4ED6-A22A-F3188909832C**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 8BA0EEC8-B929-4ED6-A22A-F3188909832C

**Date Sent:** 12/25/2014

SSO  Bypass  Upset

**Facility Permit Number:** AR0033278  
**Date Overflow Began:** 12/24/2014  
**Date Overflow Ended:** 12/24/24  
**Location:**

**Facility name:** P Street WWTP  
**Time:** 2:45 pm  
**Time:** 4:25 pm

3115 Cliff Drive MC07-1570

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Volume:** 500

(Give an estimate in gallons)

**Impact of SSO Event:** SSO Reached Public Land Only (ground)

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded  Disinfected and Deodorized
- Jet-Vac  Hydro Cleaned
- Hand rodded  Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment  Public Notification
- Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact  NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact  EFK - Evidence of Fish Kill

Reported By **Steve Floyd** Title **Supt.** Telephone Number **(479) 784-2331**

Additional Comments if Needed: Cleanup scheduled



**CONFIRMATION NUMBER**

**DEF2E7CD-8B1B-404E-A1AC-13E69BA243F3**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** DEF2E7CD-8B1B-404E-A1AC-13E69BA243F3  
**Date Sent:** 12/30/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0021750**  
 Date Overflow Began: **12/29/2014**  
 Date Overflow Ended: **12/29/2014**  
 Location:

Facility name: **Massard**  
 Time: **9:55 am**  
 Time: **11:40 am**

**2302 North 50th Street, Manhole number S005-1010, overflow reached adjacent roadside drainage ditch**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Volume: 525**

(Give an estimate in gallons)

**Impact of SSO Event: SSO Reached Receiving Water (river,stream)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Parke**

Title **Director of Utilities**

Telephone Number **(479) 784-2231**

Additional Comments if Needed: **Clean up of site scheduled**

**CONFIRMATION NUMBER**

**8C85792D-E7EA-4A21-88C0-28B0D11525D3**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 8C85792D-E7EA-4A21-88C0-28B0D11525D3

**Date Sent:** 12/30/2014

SSO  Bypass  Upset

Facility Permit Number:

**AR0021750**

Facility name:

**Massard WWTP**

Date Overflow Began:

**12/30/2014**

Time:

**10:20 am**

Date Overflow Ended:

**12/30/2014**

Time:

**11:00 am**

Location:

**4421 Royal Oak Drive  
S007-0380 Manhole Overflow**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Volume:**

**200**

(Give an estimate in gallons)

**Impact of SSO Event:**

**SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Supt.**

Telephone Number **(479) 461-0914**

Additional Comments if Needed: cleanup scheduled

**CONFIRMATION NUMBER**

**A9D13A63-CF5E-47A6-A7EF-508D0CD76917**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** A9D13A63-CF5E-47A6-A7EF-508D0CD76917

**Date Sent:** 12/31/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**  
 Date Overflow Began: **12/31/2014**  
 Date Overflow Ended: **12/31/2014**

Facility name: **P Street**  
 Time: **12:10 pm**  
 Time: **1:50 pm**

Location: **3200 Russell Street, between manhole number W001-1310 and W001-1320, overflow reached nearby drainage dit**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Volume:** **500**

(Give an estimate in gallons)

**Impact of SSO Event:** **SSO Reached Receiving Water (river,stream)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Parke**

Title **Director of Utilities**

Telephone Number **(479) 784-2231**

Additional Comments if Needed: **Overflow type was leakage through exposed pipe joint.**

**CONFIRMATION NUMBER**

**0B9FCA8C-B482-4A3B-AAB5-55D5EF811503**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#: 0B9FCA8C-B482-4A3B-AAB5-55D5EF811503**

**Date Sent: 1/1/2015**

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street WWTP**

Date Overflow Began: **12/31/2014**

Time:

**4:20 pm**

Date Overflow Ended: **12/31/2014**

Time:

**5:02 pm**

Location:

**3400 Division St. S008-1252**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Volume:**

**42**

*(Give an estimate in gallons)*

**Impact of SSO Event:**

**SSO Reached Public Land Only (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Disinfected and Deodorized
- Jet-Vac
- Hydro Cleaned
- Hand rodded
- Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment
- Public Notification

Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd** Title **Supt.** Telephone Number **(479) 784-2331**

Additional Comments if Needed:

Area cleaned.

Monthly SSO Report December 2014

Permit Number	Manhole Number	Location	Receiving Water	Duration	Cause	Volume	Component	Date	Started	Stopped	Steps Taken
AR0021750	S003-1666 to 1665	4619 South Q Street	Yard-Private Property	171 min	Roots	171 gal	Service Line-Cleanout	12/2/2014	6:39 PM	10:30 PM	Machine Rodded, Power Jet, cleanup
AR0021750	Z004-0934	3008 Glen Flora Way	Yard-Private Property	92 min	Roots	92 gal	Manhole	12/12/2014	10:28 AM	12:30 PM	Machine Rodded, cleanup
AR0021750	S009-0920 to 0910	3404 North 47th Street	Yard-Private Property	33 min	Roots	66 gal	Service Line-Cleanout	12/14/2014	4:06 PM	4:39 PM	Machind Rodded, cleanup
AR0021750	S003-1660 to 1650	4619 South Q Street	Yard-Private Property	107 min	Line Break	107 gal	Service Line-Cleanout	12/14/2014	2:00 PM	3:47 PM	Power Jet, cleanup
AR0033278	P007-0640-0630	3630 Barry Ave.	Yard-Private Property	77 min	Roots, Debris	77 gal	Service Line-Cleanout	12/13/2014-12/14/2014	11:30 PM	12:47 AM	Machine Rodded, cleanup
AR0033278	Z005-0550	2501 Glen Flora Way	Storm Drain	70 min	Roots	1750 gal	Manhole	12/15/2014	2:10 PM	3:20 PM	Machine Rodded, cleanup
AR0033278	MC05-2280	2408 South Houston Street	Public Land-Ground	165 min	Line Break	3125 gal	Manhole	12/16/2014	3:15 PM	6:00 PM	Machine Rodded, Power Jet, cleanup
AR0021750	S008-0460 to 0480	2115 North 47th Terrace	Private Property-Building	50 min	Grease	500 gal	Service Line	12/17/2014	9:30 PM	10:20 PM	Power Jet
AR0033278	P010-0810 to 0820	104 North 13th Street	Private Property-Building	70 min	Roots	1050 gal	Service Line	12/17/2014	8:05 PM	9:15 PM	Power Jet
AR0033278	P006-1840 to 1830	1118 South 24th Street	Private Property-Building	60 min	Grease	600 gal	Service Line	12/19/2014	3:20 PM	4:20 PM	Power Jet
AR0033278	MC06-2100 to 2090	4112 South 16th Street	Yard-Private Property	90 min	Grease	450 gal	Service Line-Cleanout	12/20/2014	11:30 AM	1:00 PM	Power Jet, cleanup
AR0033278	Z004-0810 to 0800	3101 Fincastle Drive	Yard-Private Property	65 min	Roots	130 gal	Service Line-Cleanout	12/23/2014	12:25 PM	1:30 PM	Machine Rodded, cleanup
AR0033278	CS01-1220 to 0770	7100 Hwy 271 South	Public Land-Ground	60 min	Grease	600 gal	Main Line Overflow	12/23/2014	12:45 PM	1:45 PM	Power Jet, cleanup
AR0033278	P010-0810 to 0820	104 North 13th Street	Private Property-Building	50 min	Grease	50 gal	Service Line	12/23/2014	8:40 AM	9:15 AM	Machine Rodded
AR0021750	M003-1910	4001 Glen Flora Way	Yard-Private Property	110 min	Roots	550 gal	Manhole	12/23/2014	8:25 PM	10:15 PM	Machine Rodded, cleanup
AR0033278	MC07-1570	3115 Cliff Drive	Public Land-Ground	100 min	Roots	500 gal	Manhole	12/24/2014	2:45 PM	4:25 PM	Machine Rodded, cleanup
AR0021750	S005-1010	2302 North 50th Street	Public Land-Ditch	105 min	Roots, Grease	525 gal	Manhole	12/29/2014	9:55 AM	11:40 AM	Machine Rodded, cleanup
AR0021750	S007-0380	4421 Royal Oak Drive	Yard-Private Property	40 min	Roots	200 gal	Manhole	12/30/2014	10:20 AM	11:00 AM	Power Jet, cleanup
AR0033278	W001-1310 to 1320	3200 Russell Street	Public Land-Ditch	100 min	Line Break	500 gal	Main Line Overflow	12/31/2014	12:10 PM	1:50 PM	Power Jet, cleanup
AR0033278	S008-1252	3400 Division Street	Public Land-Ground	42 min	Roots	42 gal	Manhole	12/31/2014	4:20 PM	5:02 PM	Machine Rodded, cleanup