

Monthly SSO Report August 2014

Permit Number	Manhole Number	Location	Receiving Water	Duration	Cause	Volume	Component	Date	Started	Stopped	Steps Taken
AR0021750	HP01-0050	10800 Hunters Point	Yard	137 minutes	Grease	600 gal.	Manhole	8/2/2014	3:15 PM	5:32 PM	Power Jet
AR0033278	Z005-0420	2809 Heather Oaks	Yard	165 minutes	Roots	750 gal.	Manhole	8/4/2014	1:15 PM	4:00 PM	Machine Rodded
AR0033278	P004-0740 to 0600	2200 Edwards Street	Storm Drain	140 minutes	Line Failure	200 gal.	Sewer Line	8/15/2014	12:20 PM	2:40 PM	Machine Rodded/Line Repair
AR0033278	FL01-1090 to 1080	3427 Short Wilma	Yard/Storm Drain	45 minutes	Line Release/Grease	350 gal.	Sewer Line	8/15/2014	1:25 PM	2:10 PM	Power Jet
AR0021750	M001-0040	10301 Mayo Drive	Massard Creek	123 minutes	Power Outage-Storm	85485 gal.	Manhole	8/18/2014	3:18 PM	5:21 PM	OGE notified. Power restored at 5:21 PM
AR0033278	M002-0360 to 0350	4206 South 89th Street	Yard	60 minutes	Grease	300 gal.	Service Line Clean Out	8/21/2014	9:10 AM	10:10 AM	Power Jet
AR0033278	Z006-1550 to 1540	8128 Cypress Ave.	Yard	40 minutes	Roots/Grease	200 gal.	Service Line Clean Out	8/29/2014	9:35 AM	10:15 AM	Power Jet
AR0033278	P008-0150 to 0140	920 North 32nd Street	Yard	88 minutes	Debris	440 gal.	Service Line Clean Out	8/29/2014	6:47 PM	8:15 PM	Power Jet

CONFIRMATION NUMBER

76040346-8A36-4C3E-838F-9DCCB9DB9B22

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 76040346-8A36-4C3E-838F-9DCCB9DB9B22

Date Sent: 8/30/2014

SSO Bypass Upset

Facility Permit Number: **AR0033278**
Date Overflow Began: **08/29/2014**
Date Overflow Ended: **08/29/2014**
Location:

Facility name: **P Street WWTP**
Time: **6:47 pm**
Time: **8:15 pm**

920 N 32nd Street. Basin: P008. USMH: 0150 DSMH: 0140

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **Clean out**

(Enter overflow type if not listed)

Volume: **440**

(Give an estimate in gallons)

Impact of SSO Event: **SSO Reached Public Land Only (ground)**

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd** Title **Supt.** Telephone Number **(479) 784-2331**

Additional Comments if Needed: **Clean up scheduled**

CONFIRMATION NUMBER

3BBD7A87-35F4-4C96-9A81-196129B1F9D3

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 3BBD7A87-35F4-4C96-9A81-196129B1F9D3

Date Sent: 8/29/2014

SSO Bypass Upset

Facility Permit Number:

AR0033278

Facility name:

P Street WWTP

Date Overflow Began:

08/29/2014

Time:

9:35 am

Date Overflow Ended:

08/29/2014

Time:

10:15 am

Location:

8128 Cypress Ave Basin: Z006 USMH: 1550 DSMH: 1540 Cross Street: Holly

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Volume:

200

(Give an estimate in gallons)

Impact of SSO Event:

SSO Affected Private Property (ground)

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Superintendent**

Telephone Number **(479) 784-2331**

Additional Comments if Needed:

Further clean up scheduled.

CONFIRMATION NUMBER

9A9BD628-5753-4CB2-8CDE-7F28A3E29A81

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 9A9BD628-5753-4CB2-8CDE-7F28A3E29A81

Date Sent: 8/21/2014

SSO Bypass Upset

Facility Permit Number: **AR0033278**

Facility name:

P Street WWTP

Date Overflow Began: **08/21/2014**

Time:

9:10 am

Date Overflow Ended: **08/21/2014**

Time:

10:10 am

Location: **4206 South 89th Street Basin: M002 USMH: 0360 DSMH: 0350**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **Service Line Clean Out**

(Enter overflow type if not listed)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Volume: **300**

(Give an estimate in gallons)

Impact of SSO Event: **SSO Affected Private Property (ground)**

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Superintendent**

Telephone Number **(479) 784-2331**

Additional Comments if Needed: **Clean up scheduled.**

CONFIRMATION NUMBER

C1F56FE0-63B5-4FF2-B930-6BA7473391D2

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: C1F56FE0-63B5-4FF2-B930-6BA7473391D2

Date Sent: 8/19/2014

SSO Bypass Upset

Facility Permit Number:	AR0021750	Facility name:	Massard WWTP
Date Overflow Began:	08/18/2014	Time:	3:18 pm
Date Overflow Ended:	08/18/2014	Time:	5:21 pm
Location:	10301 Mayo Drive Basin: M001 USMH: 0040 DSMH: 0030 Cross Street: Rogers Ave.		

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Volume: **85485**

(Give an estimate in gallons)

Impact of SSO Event: **SSO Reached Receiving Water (river,stream)**

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded Disinfected and Deodorized
- Jet-Vac Hydro Cleaned
- Hand rodded Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment Public Notification
- Other: Describe **OG&E Notified of Outage**

Environmental Damage

- OEHC - Observed or Evidence of Human Contact NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact EFK - Evidence of Fish Kill

Reported By **Steve Floyd** Title **Superintendent** Telephone Number **(479) 784-2331**

Additional Comments if Needed: Power failure at the Massard pump station caused by severe thunderstorms and flash flooding. Manhole overflow into Massard Creek. Cleanup is scheduled. Power restored at 5:21 pm.

CONFIRMATION NUMBER

12149E41-B240-4BF5-820B-9B9C84A08AAF

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 12149E41-B240-4BF5-820B-9B9C84A08AAF

Date Sent: 8/15/2014

SSO Bypass Upset

Facility Permit Number:	AR0033278	Facility name:	P Street
Date Overflow Began:	08/15/2014	Time:	01:25 pm
Date Overflow Ended:	08/15/2014	Time:	02:10 pm
Location:	3427 Short Wilma, between manhole FL01-1090 and FL01-1080, surfacing on ground		

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **main line release**

(Enter overflow type if not listed)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Volume: **350**

(Give an estimate in gallons)

Impact of SSO Event: **SSO Reached Receiving Water (river,stream)**

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- | | |
|--|--|
| <input type="checkbox"/> Machine rodded | <input checked="" type="checkbox"/> Disinfected and Deodorized |
| <input type="checkbox"/> Jet-Vac | <input checked="" type="checkbox"/> Hydro Cleaned |
| <input type="checkbox"/> Hand rodded | <input type="checkbox"/> Spread Lime on Affected Area |
| <input type="checkbox"/> Used Generator To Power Pumps/Equipment | <input type="checkbox"/> Public Notification |
| <input type="checkbox"/> Other: Describe | |

Environmental Damage

- OEHC - Observed or Evidence of Human Contact NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact EFK - Evidence of Fish Kill

Reported By **Steve Parke** Title **Director of Utilities** Telephone Number **(479) 784-2231**

Additional Comments if Needed:

CONFIRMATION NUMBER

1D42F7E7-F87D-4AFE-9A0E-B431496969B4

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 1D42F7E7-F87D-4AFE-9A0E-B431496969B4

Date Sent: 8/15/2014

SSO Bypass Upset

Facility Permit Number: **AR0033278**

Facility name: **P Street**

Date Overflow Began: **08/15/2014**

Time: **12:20 pm**

Date Overflow Ended: **08/15/2014**

Time: **02:40 pm**

Location: **2200 Edwards Street, between manhole P004-0740 and P004-0600, line segment leak into storm drain**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **main line release**

(Enter overflow type if not listed)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Volume: **200**

(Give an estimate in gallons)

Impact of SSO Event: **SSO Reached Receiving Water (river,stream)**

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded Disinfected and Deodorized
- Jet-Vac Hydro Cleaned
- Hand rodded Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment Public Notification
- Other: Describe

Environmental Damage

- OEHC - Observed or Evidence of Human Contact NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact EFK - Evidence of Fish Kill

Reported By **Steve Parke**

Title **Director of Utilities**

Telephone Number **(479) 784-2231**

Additional Comments if Needed:

CONFIRMATION NUMBER

9857A6E7-531E-4DB6-AB68-0059F8169451

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 9857A6E7-531E-4DB6-AB68-0059F8169451

Date Sent: 8/5/2014

SSO Bypass Upset

Facility Permit Number: **AR0033278**

Facility name: .

P Street WWTP

Date Overflow Began: **08/04/2014**

Time:

01:15 pm

Date Overflow Ended: **08/04/2014**

Time:

04:00 pm

Location: **2809 Heather Oaks, cross street Jenny Lind. USMH: 0420 DSMH: 0410 Basin:2005 Manhole overflow into yard.**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

Cause of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

(Enter overflow type if not listed)

Volume: **750**

(Give an estimate in gallons)

Impact of SSO Event: **SSO Affected Private Property (ground)**

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded Disinfected and Deodorized
- Jet-Vac Hydro Cleaned
- Hand rodded Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment Public Notification
- Other: Describe

Environmental Damage

- OEHC - Observed or Evidence of Human Contact NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Supt.**

Telephone Number **(479) 461-0914**

Additional Comments if Needed: Clean up is scheduled.

CONFIRMATION NUMBER

44B2FA73-2CBF-423C-A9C4-2627B1B8D3F5

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

[Close this window](#) [Print this page](#)

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 44B2FA73-2CBF-423C-A9C4-2627B1B8D3F5

Date Sent: 8/2/2014

SSO Bypass Upset

Facility Permit Number: **AR0021750**
Date Overflow Began: **08/02/2014**
Date Overflow Ended: **08/02/2014**
Location:

Facility name: **Massard WWTP**
Time: **03:15 pm**
Time: **05:32 pm**

10800 Hunters Point Ct. Basin: HP01. USMH: 0050. DSMH: 0020 Yard overflow.

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Volume: **600**

(Give an estimate in gallons)

Impact of SSO Event: **SSO Reached Receiving Water (river,stream)**

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Disinfected and Deodorized
- Jet-Vac
- Hydro Cleaned
- Hand rodded
- Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment
- Public Notification
- Other: Describe

Environmental Damage

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd** Title **Supt.** Telephone Number **(479) 461-0914**

Additional Comments if Needed: **Clean up scheduled.**

From: (479) 784-2330
Steve Floyd
City of Fort Smith
3900 Kelley Highway

Origin ID: FSMA



J14201406190326

Fort Smith, AR 72904

Ship Date: 17SEP14
ActWgt: 0.5 LB
CAD: 1731127/NET3550

Delivery Address Bar Code



Ref #
Invoice #
PO #
Dept #

SHIP TO: (501) 682-0638 **BILL SENDER**
NPDES Enforcement Section, Water
ADEQ
5301 Northshore Drive


North Little Rock, AR 72118

MON - 22 SEP AA
EXPRESS SAVER


TRK# 7711 8810 0142
0201

72118
AR-US
LIT

SA LITA



522G1/CDB4/8AC9



After printing this label:

1. Use the 'Print' button on this page to print your label to your laser or inkjet printer.
2. Fold the printed page along the horizontal line.
3. Place label in shipping pouch and affix it to your shipment so that the barcode portion of the label can be read and scanned.

Warning: Use only the printed original label for shipping. Using a photocopy of this label for shipping purposes is fraudulent and could result in additional billing charges, along with the cancellation of your FedEx account number.

Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com. FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery, misdelivery, or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim. Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental, consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss. Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our ServiceGuide. Written claims must be filed within strict time limits, see current FedEx Service Guide.