

CONFIRMATION NUMBER

5C8BE4A5-66BB-4BBF-BAFD-C8F83BA1F7B2

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

Close this window Print this page

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 5C8BE4A5-66BB-4BBF-BAFD-C8F83BA1F7B2

Date Sent: 9/29/2014

SSO  Bypass  Upset

Facility Permit Number: AR0033278

Facility name:

P Street WWTP

Date Overflow Began: 9/28/2014

Time:

2:00 pm

Date Overflow Ended: 9/28/2014

Time:

5:00 pm

Location: 3800 Towson Ave. Basin: MC04 Overflow from Manhole # 0137. Loss of incoming power at the Millcreek Pump Station. Limbs fell across power lines.

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
 Lift Station Overflow
 Main Line Overflow
 Service Line Overflow
 Other Overflow Type:

(Enter overflow type if not listed)

Cause of Overflow

- I & I - Rainfall
 Roots
 Grease
 Debris
 Equipment Failure
 Construction
 Vandalism
 Power Failure
 Line Failure/Break
 Other Cause:

Volume: 900

(Give an estimate in gallons)

Impact of SSO Event: SSO Reached Public Land Only (ground)

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded  Disinfected and Deodorized
 Jet-Vac  Hydro Cleaned
 Hand rodded  Spread Lime on Affected Area
 Used Generator To Power Pumps/Equipment  Public Notification
 Other: Describe

Notified OG&E

Environmental Damage

- OEHC - Observed or Evidence of Human Contact  NEAH - No Evidence of Adverse Health/Environmental Impact
 OEEI - Observed or Evidence of Environmental Impact  EFK - Evidence of Fish Kill

Reported By Steve Floyd

Title Supt.

Telephone Number (479) 784-2331

Additional Comments if Needed: cleanup scheduled

**CONFIRMATION NUMBER**

**71E4A570-E78C-4CD5-BC8F-272148DD5BC3**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 71E4A570-E78C-4CD5-BC8F-272148DD5BC3

**Date Sent:** 9/29/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street WWTP**

Date Overflow Began: **9/28/2014**

Time:

**2:00 pm**

Date Overflow Ended: **9/28/2014**

Time:

**5:00 pm**

Location: **5703 Jenny Lind Rd. Basin Z001 Overflow from Manhole #0470 Loss of incoming power at the Millcreek Pump Sta**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:** **900**

(Give an estimate in gallons)

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded  Disinfected and Deodorized
- Jet-Vac  Hydro Cleaned
- Hand rodded  Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment  Public Notification
- Other: Describe **Notified OG&E**

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact  NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact  EFK - Evidence of Fish Kill

Reported By **Steve Floyd** Title **Superintendent** Telephone Number **(479) 784-2331**

Additional Comments if Needed: cleanup scheduled

**CONFIRMATION NUMBER**

**92B5E29F-80C8-45A5-B47F-1705B300F795**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#: 92B5E29F-80C8-45A5-B47F-1705B300F795**

**Date Sent: 9/29/2014**

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street WWTP**

Date Overflow Began: **9/28/2014**

Time:

**2:00 pm**

Date Overflow Ended: **9/28/2014**

Time:

**5:00 pm**

Location: **5601 Jenny Lind Rd. Basin MC06 Overflow from Manhole #1970 Loss of incoming power at the Millcreek Pump St.**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume: 900**

*(Give an estimate in gallons)*

**Impact of SSO Event: SSO Reached Public Land Only (ground)**

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded  Disinfected and Deodorized
- Jet-Vac  Hydro Cleaned
- Hand rodded  Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment  Public Notification
- Other: Describe **Notified OG&E**

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact  NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact  EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Supt.**

Telephone Number **(479) 784-2331**

Additional Comments if Needed: cleanup scheduled

**CONFIRMATION NUMBER**

**14D4BD5B-A634-41A1-AD18-B7D484F6198E**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 14D4BD5B-A634-41A1-AD18-B7D484F6198E

**Date Sent:** 9/29/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street WWTP**

Date Overflow Began: **9/28/2014**

Time:

**2:00 pm**

Date Overflow Ended: **9/28/2014**

Time:

**5:00 pm**

Location: **5218 South 17th Terrace Basin: MC06 Manhole: 1280 Loss of incoming power at the Millcreek Pump Station.**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Volume: 1800**

(Give an estimate in gallons)

**Impact of SSO Event: SSO Reached Public Land Only (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded  Disinfected and Deodorized
- Jet-Vac  Hydro Cleaned
- Hand rodded  Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment  Public Notification
- Other: Describe **Notified OG&E**

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact  NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact  EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Supt.**

Telephone Number **(479) 784-2331**

Additional Comments if Needed: cleanup scheduled

**CONFIRMATION NUMBER**

**6FA124CB-3F4A-4F23-A35F-2AC719B02767**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 6FA124CB-3F4A-4F23-A35F-2AC719B02767

**Date Sent:** 9/26/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0021750**

Facility name:

**Massard WWTP**

Date Overflow Began: **9/26/2014**

Time:

**2:30 pm**

Date Overflow Ended: **9/26/2014**

Time:

**3:15 pm**

Location: **4818 South 31st Street Basin: 2001 USMH: 2490 DSMH: 2480 Overflow at clean out in yard.**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:** **225**

*(Give an estimate in gallons)*

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Disinfected and Deodorized
- Jet-Vac
- Hydro Cleaned
- Hand rodded
- Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment
- Public Notification
- Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Supt.**

Telephone Number **(479) 784-2331**

Additional Comments if Needed: **clean up scheduled.**

**CONFIRMATION NUMBER**

**3223E664-E738-40BC-9925-CE990FD79B83**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 3223E664-E738-40BC-9925-CE990FD79B83

**Date Sent:** 9/24/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street WWTP**

Date Overflow Began: **9/23/2014**

Time:

**4:50 pm**

Date Overflow Ended: **9/23/2014**

Time:

**6:50 pm**

Location: **2720 South S Street Basin P009 USMH: 0380 DSMH: 0370 Manhole Overflow 0380**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Volume: 600**

(Give an estimate in gallons)

**Impact of SSO Event: SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded  Disinfected and Deodorized
- Jet-Vac  Hydro Cleaned
- Hand rodded  Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment  Public Notification
- Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact  NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact  EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Superintendent**

Telephone Number **(479) 784-2331**

Additional Comments if Needed: cleanup scheduled

**CONFIRMATION NUMBER**

**88AF5FD0-4401-41FB-A6E2-6DC7D3B49B9D**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 88AF5FD0-4401-41FB-A6E2-6DC7D3B49B9D

**Date Sent:** 9/18/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0021750**

Facility name:

**Massard WWTP**

Date Overflow Began: **9/17/2014**

Time:

**9:00 pm**

Date Overflow Ended: **9/17/2014**

Time:

**10:00 pm**

Location:

**South 31st Street Cross Street: Vicksburg  
Manhole overflow due to wet weather event.  
Downstream of Zero Street Pump Station.**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Volume:** **60**

*(Give an estimate in gallons)*

**Impact of SSO Event:** **SSO Reached Public Land Only (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded  Disinfected and Deodorized
- Jet-Vac  Hydro Cleaned
- Hand rodded  Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment  Public Notification
- Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact  NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact  EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Supt.**

Telephone Number **(479) 784-2331**

Additional  
Comments  
if Needed:

**CONFIRMATION NUMBER**

**F2BC9C59-DA69-404D-81F5-7CE97508FA4E**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** F2BC9C59-DA69-404D-81F5-7CE97508FA4E

**Date Sent:** 9/18/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street WWTP**

Date Overflow Began: **9/17/2014**

Time:

**11:25 pm**

Date Overflow Ended: **9/18/2014**

Time:

**6:00 am**

Location:

**1412 Phoenix Avenue Basin: MC06 Manhole No. 0305  
Manhole overflow due to a wet weather event.**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Volume: 7900**

(Give an estimate in gallons)

**Impact of SSO Event: SSO Reached Public Land Only (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Supt.**

Telephone Number **(479) 784-2331**

Additional Comments if Needed: **clean up scheduled.**



**CONFIRMATION NUMBER**

**51108AC6-50B1-43FF-B33F-F0F840B0B720**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 51108AC6-50B1-43FF-B33F-F0F840B0B720  
**Date Sent:** 9/18/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**  
 Date Overflow Began: **9/17/2014**  
 Date Overflow Ended: **9/17/2014**

Facility name: **P Street WWTP**  
 Time: **8:35 pm**  
 Time: **11:30 pm**

Location: **400 North 20th Street Basin P005 Manhole No. 1920 Manhole overflow due to a wet weather event.**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:** **1750**

*(Give an estimate in gallons)*

**Impact of SSO Event:** **SSO Reached Public Land Only (ground)**

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd** Title **Supt.** Telephone Number **(479) 784-2331**

Additional Comments if Needed:

**CONFIRMATION NUMBER**

**01A4465C-4D2A-471C-9229-8F452ECA3A93**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 01A4465C-4D2A-471C-9229-8F452ECA3A93

**Date Sent:** 9/17/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street WWTP**

Date Overflow Began: **9/17/2014**

Time:

**1:05 pm**

Date Overflow Ended: **9/17/2014**

Time:

**3:10 pm**

Location: **4817 Kelley Hwy Basin S009 USMH: 0160 DSMH: 0150 Overflow at manhole 0160 onto yard.**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Volume: 625**

*(Give an estimate in gallons)*

**Impact of SSO Event: SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Supt.**

Telephone Number **(479) 784-2331**

Additional Comments if Needed: **Clean up scheduled.**

**CONFIRMATION NUMBER**

**52B2413B-61A1-4237-A389-A71C73B27BAE**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#: 52B2413B-61A1-4237-A389-A71C73B27BAE**

**Date Sent: 9/16/2014**

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street WWTP**

Date Overflow Began: **09/15/2014**

Time:

**06:50 pm**

Date Overflow Ended: **09/15/2014**

Time:

**08:50 pm**

Location: **2501 Glen Flora Way Basin: Z005 USMH: 0560 DSMH: 0550 Main line stoppage, overflow in driveway.**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume: 2400**

*(Give an estimate in gallons)*

**Impact of SSO Event: SSO Reached Receiving Water (river,stream)**

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Disinfected and Deodorized
- Jet-Vac
- Hydro Cleaned
- Hand rodded
- Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment
- Public Notification
- Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd** Title **Supt.** Telephone Number **(479) 784-2331**

Additional Comments if Needed: **clean up scheduled.**

**CONFIRMATION NUMBER**

**E86D8174-19F1-4084-9F6F-AEB49EA1EEA9**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** E86D8174-19F1-4084-9F6F-AEB49EA1EEA9

**Date Sent:** 9/15/2014

SSO  Bypass  Upset

Facility Permit Number:

**AR0033278**

Facility name:

**P Street WWTP**

Date Overflow Began:

**09/11/2014**

Time:

**02:15 pm**

Date Overflow Ended:

**09/11/2014**

Time:

**03:00 pm**

Location:

**3904 Parke Ave. Basin: P007 USMH: 0760 DSMH: 0740  
Sewer main blockage resulting in backup into house and overflow in yard.**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:**

**unknown**

*(Give an estimate in gallons)*

**Impact of SSO Event:**

**SSO Affected Private Property (ground)**

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Supt.**

Telephone Number **(479) 784-2331**

Additional Comments if Needed: clean up scheduled

CONFIRMATION NUMBER

ODB141E2-1DBD-4680-B106-C8A74DC1EA94

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

Close this window Print this page

24-Hour Sanitary Sewer Overflow Report

SSO ID#: ODB141E2-1DBD-4680-B106-C8A74DC1EA94

Date Sent: 9/11/2014

SSO  Bypass  Upset

Facility Permit Number: AR0033278

Facility name: P Street WWTP

Date Overflow Began: 09/11/2014

Time: 01:20 pm

Date Overflow Ended: 09/11/2014

Time: 03:00 pm

Location: 1900 Wheeler Ave. Basin: MC03 USMH: 0140 DSMH: 0130 Overflow into yard.

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
 Lift Station Overflow
 Main Line Overflow
 Service Line Overflow
 Other Overflow Type:

(Enter overflow type if not listed)

Volume: 1000

(Give an estimate in gallons)

Impact of SSO Event: SSO Affected Private Property (ground)

Cause of Overflow

- I & I - Rainfall
 Roots
 Grease
 Debris
 Equipment Failure
 Construction
 Vandalism
 Power Failure
 Line Failure/Break
 Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded  Disinfected and Deodorized
 Jet-Vac  Hydro Cleaned
 Hand rodded  Spread Lime on Affected Area
 Used Generator To Power Pumps/Equipment  Public Notification
 Other: Describe

Environmental Damage

- OEHC - Observed or Evidence of Human Contact  NEAH - No Evidence of Adverse Health/Environmental Impact
 OEEI - Observed or Evidence of Environmental Impact  EFK - Evidence of Fish Kill

Reported By Steve Floyd

Title Supt.

Telephone Number (479) 784-2331

Additional Comments if Needed: Cleanup scheduled.

**CONFIRMATION NUMBER**

**CB1CD432-9D01-41F6-BF7C-3E23161BD7E9**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** CB1CD432-9D01-41F6-BF7C-3E23161BD7E9  
**Date Sent:** 9/11/2014

SSO  Bypass  Upset

Facility Permit Number:	<b>AR0021750</b>	Facility name:	<b>Massard WWTP</b>
Date Overflow Began:	<b>09/11/2014</b>	Time:	<b>05:30 am</b>
Date Overflow Ended:	<b>09/11/2014</b>	Time:	<b>09:00 am</b>

Location: **Carol Ann Cross Park Cross Street: So. 74th Street Overflow at MH No. 0680 due to excessive rainfall of 2.8 inches**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Volume:** **2100**

*(Give an estimate in gallons)*

**Impact of SSO Event:** **SSO Reached Public Land Only (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- |  |  |
|--|--|
| <input type="checkbox"/> Machine rodded                          | <input checked="" type="checkbox"/> Disinfected and Deodorized |
| <input type="checkbox"/> Jet-Vac                                 | <input type="checkbox"/> Hydro Cleaned                         |
| <input type="checkbox"/> Hand rodded                             | <input type="checkbox"/> Spread Lime on Affected Area          |
| <input type="checkbox"/> Used Generator To Power Pumps/Equipment | <input type="checkbox"/> Public Notification                   |
| <input type="checkbox"/> Other: Describe                         |  |

**Environmental Damage**

- |  |   |
|--|---|
| <input type="checkbox"/> OEHC - Observed or Evidence of Human Contact        | <input checked="" type="checkbox"/> NEAH - No Evidence of Adverse Health/Environmental Impact |
| <input type="checkbox"/> OEEI - Observed or Evidence of Environmental Impact | <input type="checkbox"/> EFK - Evidence of Fish Kill  |

Reported By **Steve Floyd** Title **Supt.** Telephone Number **(479) 784-2331**

Additional Comments if Needed: **Cleanup scheduled.**

CONFIRMATION NUMBER

42AD7935-FE47-4012-B996-A1951EC9B0E2

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

Close this window Print this page

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 42AD7935-FE47-4012-B996-A1951EC9B0E2

Date Sent: 9/9/2014

SSO  Bypass  Upset

Facility Permit Number: AR0021750

Facility name:

Massard WWTP

Date Overflow Began: 09/09/2014

Time:

9:50 am

Date Overflow Ended: 09/09/2014

Time:

11:00 am

Location: 3609 South 95th Circle Basin: M007 USMH: 0500 DSMH: 0450 Overflow from defective sewer pipe caused by root blockage. Repair of line segment scheduled. Overflow to ditch.

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
 Lift Station Overflow
 Main Line Overflow
 Service Line Overflow
 Other Overflow Type:

(Enter overflow type if not listed)

Cause of Overflow

- I & I - Rainfall
 Roots
 Grease
 Debris
 Equipment Failure
 Construction
 Vandalism
 Power Failure
 Line Failure/Break
 Other Cause:

Volume: 700

(Give an estimate in gallons)

Impact of SSO Event: SSO Reached Public Land Only (ground)

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded  Disinfected and Deodorized
 Jet-Vac  Hydro Cleaned
 Hand rodded  Spread Lime on Affected Area
 Used Generator To Power Pumps/Equipment  Public Notification
 Other: Describe

Environmental Damage

- OEHC - Observed or Evidence of Human Contact  NEAH - No Evidence of Adverse Health/Environmental Impact
 OEEI - Observed or Evidence of Environmental Impact  EFK - Evidence of Fish Kill

Reported By Steve Floyd

Title Supt.

Telephone Number (479) 784-2331

Additional Comments if Needed: Clean up scheduled.

**CONFIRMATION NUMBER**

**4F25DFBF-FC15-423D-B200-4A4FEC14E0C8**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#: 4F25DFBF-FC15-423D-B200-4A4FEC14E0C8**

**Date Sent: 9/9/2014**

SSO  Bypass  Upset

Facility Permit Number: **AR0021750**

Facility name:

**Massard WWTP**

Date Overflow Began: **09/09/2014**

Time:

**9:05 am**

Date Overflow Ended: **09/09/2014**

Time:

**9:25 am**

Location: **4000 High Street Basin: S009 USMH: 1590 DSMH: 1560 Overflow to ditch.**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Volume: 100**

*(Give an estimate in gallons)*

**Impact of SSO Event: SSO Reached Public Land Only (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Supt.**

Telephone Number **(479) 784-2331**

Additional Comments if Needed: **Clean up scheduled.**



CONFIRMATION NUMBER

98748108-28AF-4DC9-8DF5-C31B05D877CA

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

The following information has been sent.

Close this window Print this page

24-Hour Sanitary Sewer Overflow Report

SSO ID#: 98748108-28AF-4DC9-8DF5-C31B05D877CA

Date Sent: 9/8/2014

SSO  Bypass  Upset

Facility Permit Number: AR0033278  
Date Overflow Began: 09/07/2014  
Date Overflow Ended: 09/07/2014

Facility name:  
Time:  
Time:

P Street  
07:01 pm  
08:45 pm

Location:

1701 Quincy Street, customer cleanout, between manholes MC06-0640 and MC06-0650

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

Type of Overflow

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

Volume: 520

(Give an estimate in gallons)

Impact of SSO Event: SSO Affected Private Property (ground)

Cause of Overflow

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

Action Taken - Check all that apply

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded  Disinfected and Deodorized
- Jet-Vac  Hydro Cleaned
- Hand rodded  Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment  Public Notification
- Other: Describe

Environmental Damage

- OEHC - Observed or Evidence of Human Contact  NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact  EFK - Evidence of Fish Kill

Reported By Steve Parke

Title Director of Utilities

Telephone Number (479) 784-2231

Additional Comments if Needed:

**CONFIRMATION NUMBER**

**AD0CA878-486F-4882-B6D5-C6D7DB0560CD**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** AD0CA878-486F-4882-B6D5-C6D7DB0560CD

**Date Sent:** 9/2/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street WWTP**

Date Overflow Began: **09/02/2014**

Time:

**09:58 am**

Date Overflow Ended: **09/02/2014**

Time:

**11:15 am**

Location: **3406 Kinkead Avenue Basin: P008 USMH: 1670 DSMH: 1650 Cross Street: North 35th Street**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Volume: 425**

(Give an estimate in gallons)

**Impact of SSO Event: SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd**

Title **Supt.**

Telephone Number **(479) 784-2331**

Additional Comments if Needed: **clean up scheduled**

Monthly SSO Report September 2014

Permit Number	Manhole Number	Location	Receiving Water	Duration	Cause	Volume	Component	Date	Started	Stopped	Steps Taken
AR0033278	#D8-1650 to 1670	3406 Kinkead Avenue	Yard	85 min.	Grease	425 gal.	Service Line Overflow	9/2/2014	9:58 AM	11:15 AM	Power Jet
AR0033278	MC06-0640 to 0650	1701 Quincey Street	Yard	104 min.	Roots/Grease	520 gal.	Service Line Overflow	9/7/2014	7:01 PM	8:45 PM	Power Jet
AR0021750	S009-1560	4000 High Street	Ditch	20 min.	Roots/Grease	100 gal.	Manhole Overflow	9/9/2014	9:05 AM	9:25 AM	Power Jet
AR0021750	M007-0500 to 0450	3609 South 95th Circle	Ditch	70 min.	Roots	700 gal.	Main Line Break	9/9/2014	9:50 AM	11:00 AM	Power Jet
AR0021750	RL01-0680	Carol Ann Cross Park	Public Land	210 min.	I & I - Rainfall	2100 gal.	Manhole Overflow	9/11/2014	5:30 AM	9:00 AM	Scheduled Cleanup
AR0033278	MC06-0350	1412 Phoenix Avenue	Storm Drain	240 min.	I & I - Rainfall	4800 gal.	Manhole Overflow	9/11/2014	4:30 AM	8:30 AM	Scheduled Cleanup
AR0033278	MC03-0140	1900 Wheeler Avenue	Yard	100 min	Grease	1000 gal.	Manhole Overflow	9/11/2014	1:20 PM	3:00 PM	Power Jet
AR0033278	P007-0760 to 0740	3904 Park Avenue	Yard/Building	Unknown	Grease	Unknown	Service Line Overflow	9/11/2014	2:15 PM	3:00 PM	Power Jet
AR0033278	Z005-0560 to 0550	2501 Glen Flora Way	Ditch	120 min.	Roots	2400 gal.	Main Line Overflow	9/15/2014	6:50 PM	8:50 PM	Power Jet/Machine Rodded
AR0033278	S009-0160	4817 Kelley Hwy	Yard	125 min.	Roots	625 gal.	Manhole Overflow	9/17/2014	1:05 PM	3:10 PM	Power Jet
AR0033278	P005-1920	400 North 20th Street	Public Land	175 min.	I & I - Rainfall	1750 gal.	Manhole Overflow	9/17/2014	8:35 PM	11:30 PM	Scheduled Cleanup
AR0033278	MC06-0305	1412 Phoenix Avenue	Storm Drain	395 min.	I & I - Rainfall	7900 gal.	Manhole Overflow	9/17/2014 to 9/18/2014	11:25 PM	6:00 AM	Scheduled Cleanup
AR0021750	Manhole at 31st and Vicksburg	South 31st Street	Ditch	60 min.	I & I - Rainfall	60 gal.	Manhole Overflow	9/17/2014	9:00 PM	10:00 PM	Scheduled Cleanup
AR0033278	P009-0380	2720 South S Street	Yard	120 min.	Roots	600 gal.	Manhole Overflow	9/23/2014	4:50 PM	6:50 PM	Machine Rodded
AR0021750	Z001-2490 to 2480	4818 South 31st Street	Yard	45 min.	Roots/Grease	225 gal.	Service Line Overflow	9/26/2014	2:30 PM	3:15 PM	Machine Rodded
AR0033278	MC06-1280	5218 South 17th Terrace	Public Land	180 min.	Power Failure	1800 gal.	Manhole Overflow	9/28/2014	2:00 PM	5:00 PM	Loss of incoming power at the Milkcreek P.S.
AR0033278	MC06-1970	5601 Jenny Lind Road	Public Land	180 min.	Power Failure	900 gal.	Manhole Overflow	9/28/2014	2:00 PM	5:00 PM	Notified OG&E Limbs fell on power lines. Loss of incoming power at the Milkcreek P.S.
AR0033278	Z001-0470	5703 Jenny Lind Road	Yard	180 min.	Power Failure	900 gal.	Manhole Overflow	9/28/2014	2:00 PM	5:00 PM	Notified OG&E Limbs fell on power lines. Loss of incoming power at the Milkcreek P.S.
AR0033278	MC04-0137	3800 Towson Avenue	Yard	180 min.	Power Failure	900 gal.	Manhole Overflow	9/28/2014	2:00 PM	5:00 PM	Notified OG&E Limbs fell on power lines. Loss of incoming power at the Milkcreek P.S.