Monthly SSO Report January 2015											
Permit Number AR0033278	Manhole Number	Location	Receiving Water	Duration	Cause	Volume	Component	Date	Started	Stopped	Steps Taken
	MC05-2690 to 2700	2914 Houston	Private Property	44 min	Grease	220 gal	Service line overflow	1/2/2015	11:01 AM	11:45 AM	Jet-Vac, cleanup scheduled
AR0033278	S009-0540 to 0510	3118 North 45th St.	Private Property	175 min	Roots/Grease	1750 ga!	Service line overflow	1/2/2015 - 1/3/2015	10:50 PM	1:45 AM	Machine Rodded/Power Jet, cleanup scheduled
AR0021750	M007-1210 to 1190	3220 South 62nd St.	Private Property	105 min	Grease	105 gal	Service line overflow	1/3/2015	3:00 PM	4:45 PM	Jet-Vac, disinfected and deodorized
AR0033278	MC06-0542	1412 Phoenix Ave.	Pavement/Storm Drain	347 min	I&I Excessive Rainfall	3470 gal	Manhole	1/3/2015	9:26 AM	3:13 PM	Disinfected and deodorized
AR0033278	MC06-0305	1412 Phoenix Ave.	Pavement/Storm Drain	360 min	I&I Excessive Rainfall	3600 gal	Manhole	1/3/2015	9:10 AM	3:13 PM	Cleanup scheduled
AR0033278	PO11-2450	1701 Rogers Ave.	Pavement/Storm Drain	290 min	Grease	2900 gal	Manhole	1/3/2015	10:00 AM		Machine Rodded/Power Jet, cleanup scheduled
AR0021750	RL01-0140	9 Riverlyn Terrace	Stream/River	528 min .	I&I Excessive Rainfall	5280 gal	Manhole	1/3/2015	7:22 AM	4:10 PM	Minor cleanup
AR0033278	P007- 2750 to 2730	4427 Park Avenue	Private Property	60 min	Grease	600 gal	Service line overflow	1/5/2015	11:20 AM	12:20 PM	Jet-Vac, disinfected and deodorized
AR0033278	Z001-2880	South 34th & Savannah St.	Private Property	35 min	Debris	70 gal	Manhole	1/6/2015	10:45 AM		Machine Rodded, cleanup scheduled
AR0033278	MC08-0400	2613 South Waco St.	Private Property	52 min	Debris	1560 gal	Manhole	1/7/2015	8:48 AM	9:40 AM	
AR0033278	P006-0192	South I Street & South 20th Street	Storm Drain	255 min	Storm Drain Cross Conn.	1275 gal	Manhole	1/8/2015	2:45 PM	7:00 PM	Machine Rodded, cleanup scheduled
AR0033278	MC05-2550	2700 Houston Street	Public Property	105 min	Roots	525 gal	Manhole	1/9/2015	5:00 PM	1	Constructing new line. Sand bags/pumping continue
AR0033278	Z003-1380	8723 South 30th Terrace	Stream/River	68 min	Grease	340 gal	Manhole	1/12/2015	8:15 PM	6:45 PM	Jet-Vac, cleanup scheduled
AR0033278	S005-0730 to 0720	5300 Wilson Road	Storm Drain/Yard	75 min	Roots	75 gal	Service line overflow	1/14/2015	3:55 PM	9:23 PM	Jet-Vac, disinfected and deodorized
AR0033278	P009-2140 to2135	3421 Greenwood Rd.	Storm Drain/Yard	90 min	Roots	180 gal	Service line overflow	1/15/2015		5:05 PM	Jet-Vac
AR0033278	MC05-2100/2190	2605 Dallas Street	Storm Drain	95 min	Roots	1425 gal	Manhole	1/15/2015	8:30 AM	10:00 AM	Jet-Vac, cleanup scheduled
AR0033278	FL01-0730	4601 North 33rd St.	Private Property	65 min	Grease	65 gal	Manhole		2:55 PM	4:30 PM	Machine Rodded, cleanup scheduled
AR0033278_	5009-1420 to 1410	4101 Wirsong St.	Private Property	190 min	Roots-Line Failure	190 gal	Service line overflow	1/16/2015	10:25 AM	11:30 AM	Jet-Vac, disinfected and deodorized
AR0033278	S009-0540 to 0510	3118 North 46th Street	Private Property	420 min	Line failure	420 gal	Service line overflow	1/17/2015	4:15 PM	7:25 PM	Machine Rodded, Jet-Vac, cleanup scheduled
AR0033278	Z006-1210 to 1200	8300 Colony Lane	Private Property	169 min	Roots	169 gal	Service line overflow		1:15 PM	8:00 PM	Jet-Vac, line repaired.
AR0033278	P009-2880	2900 Boston Street	Private Property/Ditch	65 min	Roots/Grease	65 gal	Manhole	1/18/2015	4:21 PM	7:10 PM	Jet-Vac, disinfected and deodorized
AR0021750	5006-1120 to 1110	815 North 46th Street	Private Property	35 min	Grease	175 gal	Service line overflow	1/20/2015	9:10 AM	10:15 AM	Jet-Vac, disinfected and deodorized
AR0033278	MC02-0960 to 0950	1905 Lexington Street	Public Property	30 min	Debris	150 gal		1/20/2015	8:30 AM	9:05 AM	Jet-Vac, disinfected and deodorized
AR0021750	5001-0120 to 0110	933 South 68th Lane	Private Property	75 min	Roots		Service line overflow	1/21/2015	1:45 PM	2:15 PM	Removed debris from flat line segment
AR0021750	S003-1660 to 1650	4619 South Q Street	Storm Drain/Ditch	163 min	Debris	75 gal 326 gal	Service line overflow	1/22/2015	8:45 AM	10:00 AM	Jet-Vac, disinfected and deodorized
AR0033278	FL01-1130	3632 Northview Drive	Stream/River	60 min	Grease		Service line overflow	1/24/2015	10:50 AM	1:17 PM	Jet-Vac, cleanup scheduled
AR0033278	CS01-0270	7320 Cherly Lane	Stream/River	40 min		60 gal	Manhole	1/26/2015	8:15 AM	9:15 AM	Jet-Vac, disinfected and deodorized, public notification
AR0033278	CS01-0270	7320 Cherly Lane	Stream/River	35 min	Roots	200 gal	Manhole	1/27/2015	9:30 AM	10:15 AM	Jet-Vac, disinfected and deodorized
AR0033278	Z006-1900 to 1880	8220 Hwy 271 South	Private Property	95 min		175 gal	Manhole	1/28/2015			Jet-Vac, disinfected and deodorized
AR0033278	Z002-0170	1600 Magnolia Drive	Private Property	145 min	Grease	950 gal	Service line overflow	1/30/2015	6:10 PM	7:45 PM	Jet-Vac, disinfected and deodorized
			Frivate Property	145 min	Grease	1450 gal	Manhole	1/30/2015	7:50 PM	10:15 PM	Jet-Vac, disinfected and deodorized
		<u> </u>		 		-			1		
	-	 							<u> </u>	I	
						-			<u> </u>		
· · · · · · · · · · · · · · · · · · ·						 					
January 2015 Monthly SS	O Report					<u> </u>					
City of Fort Smith Utility Department						ļ				!	
- ,		<u> </u>		<u> </u>	<u> </u>	1			1		