

Monthly SSO Report February 2014

Permit Number	Manhole Number	Location	Receiving Water	Duration	Cause	Volume	Component	Date	Started	Stopped	Steps Taken
AR0021750	Z004-110	3128 Glen Flora Way	yard	100 minutes	grease	500 gallons	manhole	2/2/2014	8:40 AM	10:20 AM	Hydro cleaned
AR0033278	between P008-1375 & 1370	428 Melrose	yard	40 minutes	root, grease & damage	200 gallons	service line	2/5/2014	4:42 PM	5:22 PM	Machine rodded & repaired (by plumber)
AR0033278	FL01-1560	3112 Emrich	ditch	60 minutes	debris	300 gallons	manhole	2/7/2014	10:30 AM	11:30 AM	Machine rodded
AR0033278	RL01-0760/0749	2620 Riviera Cir	yard	195 minutes	roots & debris	975 gallons	manhole	2/7/2014	2:45 PM	6:00 PM	Machine rodded & Hydro cleaned
AR0021750	between RB01-0550 & 0540	3205 So. 96	yard	67 minutes	roots	335 gallons	clean out	2/8/2014	10:00 AM	11:07 AM	Machine rodded
AR0033278	between S007-1650 & 1640	1305 No. 47	yard	165 minutes	roots & grease	825 gallons	clean out	2/9/2014	12:00 PM	2:45 PM	Hydro cleaned
AR0033278	between S007 3160 & 3150	2008 No. 46 Ter	yard	36 minutes	roots	180 gallons	clean out	2/9/2014	3:32 PM	4:08 PM	Hydro cleaned
AR0021750	Z008-0670	2505 Ramsgate Way	ditch	85 minutes	grease	425 gallons	manhole	2/10/2014	6:50 PM	8:15 PM	Hydro cleaned
AR0033278	between PL01-0180 & 0160	5400 Elm	building	90 minutes	grease	450 gallons	building	2/10/2104	8:30 PM	10:00 PM	Hydro cleaned
AR0033278	between S009-1100 & 1096	2513 No. 41	yard	120 minutes	grease	600 gallons	clean out	2/11/2014	11:00 AM	1:00 PM	Hydro cleaned
AR0033278	between FL01-1220 & 1210	3409 Short Wilma	ditch	30 minutes	roots	150 gallons	clean out	2/11/2014	11:40 AM	12:10 PM	Machine rodded
AR0021750	between MC05-0430 & 0420	3601 So. 16	yard	45 minutes	grease	225 gallons	clean out	2/13/2014	3:30 PM	4:15 PM	Hydro cleaned
AR0033278	M007-0770	2809 So. 59	yard	60 minutes	debris	300 gallons	manhole	2/17/2014	8:40 AM	9:40 AM	Machine rodded
AR0033278	between MC05-1850 & 1840	2111 Carthage	building	65 minutes	roots & debris	325 gallons	building	2/17/2014	3:45 PM	4:50 PM	Hydro cleaned
AR0033278	MC06- 1460 & 1640	1215 Hwy. 71 (correction)	paved area	60 minutes	grease	600 gallons	manhole	2/18/2014	11:10 AM	12:10 PM	Hydro cleaned
AR0033278	M006-0590	6 Old Greenwood Ln	storm drain	40 minutes	roots	200 gallons	manhole	2/19/2014	10:50 AM	11:30 AM	Machine rodded
AR0033278	between P007-0760 & 0740	3920 Park	yard	60 minutes	roots, grease & debris	300 gallons	clean out	2/24/2014 (correction)	1:40 PM	2:40 PM	Hydro cleaned
AR0033278	between MC07-0890 & 0870	4616 So. 27	yard	48 minutes	roots & grease	240 gallons	clean out	2/25/2014	3:49 PM	4:37 PM	Machine rodded
AR0033278	between P008-3100 & 3090	So. 34 & M	ditch & storm drain	181 minutes	damage	5430 gallons	main line	2/27/2014	7:45 AM	11:25 AM	Emergency repair
AR0033278	S006-0130	5205 No. O	storm drain	50 minutes	grease & debris	1250 gallons	manhole	2/27/2014	8:10 AM	9:00 AM	Machine rodded

**CONFIRMATION NUMBER**

**4A619E13-1CFD-48F7-83C6-5ED9913337C6**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 4A619E13-1CFD-48F7-83C6-5ED9913337C6  
**Date Sent:** 2/27/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**  
 Date Overflow Began: **02/27/2014**  
 Date Overflow Ended: **02/27/2014**  
 Location: **5205 No. O, manhole S006-0130, storm drain**

Facility name:  
 Time:  
 Time:

**P Street**  
**08:10 am**  
**09:00 am**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Volume:** **1,250**

*(Give an estimate in gallons)*

**Impact of SSO Event:** **SSO Reached Public Land Only (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional  
 Comments  
 if Needed:

**CONFIRMATION NUMBER**

**BE7BAE50-E4B7-4AD3-9846-EAC5FC4062F2**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** BE7BAE50-E4B7-4AD3-9846-EAC5FC4062F2

**Date Sent:** 2/27/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**  
 Date Overflow Began: **02/27/2014**  
 Date Overflow Ended: **02/27/2014**  
 Location: **So. 34 & M Steets, between manholes P008-3100 & 3090, ditch and storm drain**

Facility name:  
 Time:  
 Time:

**P Street**  
**07:45 am**  
**11:25 am**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Volume:** **5,430**

*(Give an estimate in gallons)*

**Impact of SSO Event:** **SSO Reached Public Land Only (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe **emergency repair made**
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed: **mainline line damaged by city street department construction activity**

**CONFIRMATION NUMBER**

**DE8EBE70-C401-4857-B013-599CF4679B3A**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** DE8EBE70-C401-4857-B013-599CF4679B3A

**Date Sent:** 2/26/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**  
 Date Overflow Began: **02/25/2014**  
 Date Overflow Ended: **02/25/2014**  
 Location: **4616 So. 27, between Mc07-0890 & 0870, yard**

Facility name:  
 Time:  
 Time:

**P Street**  
**03:49 pm**  
**04:37 pm**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **clean out**

*(Enter overflow type if not listed)*

**Volume: 240**

*(Give an estimate in gallons)*

**Impact of SSO Event: SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional  
 Comments  
 if Needed:

**CONFIRMATION NUMBER**

**3AC0C041-3E0B-49FB-B579-C216321C5D6F**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 3AC0C041-3E0B-49FB-B579-C216321C5D6F

**Date Sent:** 2/25/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name: **P Street**

Date Overflow Began: **02/24/2014**

Time: **01:40 pm**

Date Overflow Ended: **02/14/2014**

Time: **02:40 pm**

Location: **3920 Park Ave., between manholes P007-0760 & 0740, yard**

*correct ✓  
02/24/2014*

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **clean out**

(Enter overflow type if not listed)

**Volume:** **300**

(Give an estimate in gallons)

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

**CONFIRMATION NUMBER**

**061C96D1-B13E-453D-985B-306237CF99A3**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 061C96D1-B13E-453D-985B-306237CF99A3  
**Date Sent:** 2/20/2014

SSO  Bypass  Upset

Facility Permit Number:	<b>AR0033278</b>	Facility name:	<b>P Street</b>
Date Overflow Began:	<b>02/19/2014</b>	Time:	<b>10:50 am</b>
Date Overflow Ended:	<b>02/19/2014</b>	Time:	<b>11:30 am</b>
Location:	<b>6 Old Greenwood Rd., manhole M006-0590, storm drain</b>		

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Volume:** **200**

*(Give an estimate in gallons)*

**Impact of SSO Event:** **SSO Reached Public Land Only (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By <b>Leroy Jeremiah</b>	Title <b>Superintendent</b>	Telephone Number <b>(479) 784-2344</b>
-----------------------------------	-----------------------------	--

Additional Comments if Needed:

---

**CONFIRMATION NUMBER**

**1F3C8048-5206-4833-9E9F-05981C2258BD**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 1F3C8048-5206-4833-9E9F-05981C2258BD  
**Date Sent:** 2/19/2014

SSO  Bypass  Upset

**Facility Permit Number:** AR0033278  
**Date Overflow Began:** 02/18/2014  
**Date Overflow Ended:** 02/18/2014  
**Location:** 1215 Hwy 271 South, manhole MC06-1460 & 1640, paved area

*Corrected Hwy 271 South*

**Facility name:**  
**Time:**  
**Time:**

**P Street**  
**11:20 am**  
**12:10 pm**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:**

**600**  
(Give an estimate in gallons)

**Impact of SSO Event:**

**SSO Reached Public Land Only (ground)**

**Action Taken - Check all that apply**  
(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

**Reported By** Leroy Jeremiah

**Title** Superintendent

**Telephone Number** (479) 784-2344

**Additional Comments if Needed:**

**CONFIRMATION NUMBER**

**5C7EE04F-060C-4FD4-9529-25C7FAD964AD**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 5C7EE04F-060C-4FD4-9529-25C7FAD964AD

**Date Sent:** 2/18/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street**

Date Overflow Began: **02/17/2014**

Time:

**03:45 pm**

Date Overflow Ended: **02/17/2014**

Time:

**04:50 pm**

Location: **2111 Carthage, between MC05-1850 & 1840, building**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **building**

(Enter overflow type if not listed)

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:** **325**

(Give an estimate in gallons)

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Disinfected and Deodorized
- Jet-Vac
- Hydro Cleaned
- Hand rodded
- Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment
- Public Notification
- Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OE EI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed: **Damage claim policy for sewer backups has been forwarded to building owner**



**CONFIRMATION NUMBER**

**4E9B0E8F-3C2D-4CBD-81F8-6ECE0E90361A**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 4E9B0E8F-3C2D-4CBD-81F8-6ECE0E90361A

**Date Sent:** 2/18/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street**

Date Overflow Began: **02/17/2014**

Time:

**08:40 am**

Date Overflow Ended: **02/17/2014**

Time:

**09:40 am**

Location: **2809 So. 59, manhole M007-0770, yard**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:**

**300**

*(Give an estimate in gallons)*

**Impact of SSO Event:**

**SSO Affected Private Property (ground)**

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional  
Comments  
if Needed:

**CONFIRMATION NUMBER**

**07E8118B-9999-43BF-BB9A-73E5BCC02981**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 07E8118B-9999-43BF-BB9A-73E5BCC02981

**Date Sent:** 2/14/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0021750**  
 Date Overflow Began: **02/13/2014**  
 Date Overflow Ended: **02/13/2014**  
 Location: **3601 So. 16, between manholes MC05-0430 & 0420, yard**

Facility name: **Massard**  
 Time: **03:30 pm**  
 Time: **04:15 pm**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **clean out**

*(Enter overflow type if not listed)*

**Volume:** **225**

*(Give an estimate in gallons)*

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEL - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional  
Comments  
if Needed:

**CONFIRMATION NUMBER**

**CDA0785B-BB47-47A6-A7A4-0A643F8EB6E2**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** CDA0785B-BB47-47A6-A7A4-0A643F8EB6E2  
**Date Sent:** 2/11/2014

SSO  Bypass  Upset

Facility Permit Number:

**AR0033278**

Facility name:

**P Street**

Date Overflow Began:

**02/11/2014**

Time:

**11:40 am**

Date Overflow Ended:

**02/11/2014**

Time:

**12:10 pm**

Location:

**3409 Short Wilma, between manholes F101-1220 & 1210, ditch**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **clean out**

*(Enter overflow type if not listed)*

**Volume:**

**150**

*(Give an estimate in gallons)*

**Impact of SSO Event:**

**SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

**CONFIRMATION NUMBER**

**342076DE-0A33-497D-B1E6-8992B8D8836C**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 342076DE-0A33-497D-B1E6-8992B8D8836C  
**Date Sent:** 2/11/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**  
 Date Overflow Began: **02/11/2014**  
 Date Overflow Ended: **02/11/2014**  
 Location: **2513 No. 41, between manholes S009-1100 & 1096, yard**

Facility name:  
 Time:  
 Time:

**P Street**  
**11:00 am**  
**01:00 pm**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **clean out**

*(Enter overflow type if not listed)*

**Volume: 600**  
*(Give an estimate in gallons)*

**Impact of SSO Event: SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional  
 Comments  
 if Needed:

**CONFIRMATION NUMBER**

**CA6929EC-918A-4A9B-805A-F1D41C32D839**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** CA6929EC-918A-4A9B-805A-F1D41C32D839  
**Date Sent:** 2/11/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**  
 Date Overflow Began: **02/10/2014**  
 Date Overflow Ended: **02/10/2014**  
 Location: **5400 Elm, between PL01-0180 & 0160, building**

Facility name:  
 Time:  
 Time:

**P Street**  
**08:30 pm**  
**10:00 pm**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **building**

*(Enter overflow type if not listed)*

**Volume: 450**  
*(Give an estimate in gallons)*

**Impact of SSO Event: Basement Backup**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed: **property owner provided copy of damage claim policy and ordinance**

**CONFIRMATION NUMBER**

**8A101421-A312-4B21-8E29-1A44653C94F5**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 8A101421-A312-4B21-8E29-1A44653C94F5  
**Date Sent:** 2/11/2014

SSO  Bypass  Upset

Facility Permit Number:	<b>AR0021750</b>	Facility name:	<b>Massard</b>
Date Overflow Began:	<b>02/10/2014</b>	Time:	<b>06:50 pm</b>
Date Overflow Ended:	<b>02/10/2014</b>	Time:	<b>08:15 pm</b>
Location:	<b>2505 Ramsgate Way, manhole Z008-0670, ditch</b>		

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Volume:** **425**

*(Give an estimate in gallons)*

**Impact of SSO Event:** **SSO Reached Public Land Only (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Disinfected and Deodorized
- Jet-Vac
- Hydro Cleaned
- Hand rodded
- Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment
- Public Notification
- Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By <b>Leroy Jeremiah</b>	Title <b>Superintendent</b>	Telephone Number <b>(479) 784-2344</b>
Additional Comments if Needed:		

**CONFIRMATION NUMBER**

**9EEEEBA42-F1F7-4959-8CDC-11C846912246**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 9EEEEBA42-F1F7-4959-8CDC-11C846912246  
**Date Sent:** 2/10/2014

SSO  Bypass  Upset

Facility Permit Number:	<b>AR0033278</b>	Facility name:	<b>P Street</b>
Date Overflow Began:	<b>02/09/2014</b>	Time:	<b>03:30 pm</b>
Date Overflow Ended:	<b>02/09/2014</b>	Time:	<b>04:08 pm</b>
Location:	<b>2008 No. 46, between manhole S007-3160 &amp; 3150, yard</b>		

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **clean out**

*(Enter overflow type if not listed)*

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:**

**180**  
*(Give an estimate in gallons)*

**Impact of SSO Event:**

**SSO Affected Private Property (ground)**

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- |  |   |
|--|---|
| <input type="checkbox"/> Machine rodded                          | <input type="checkbox"/> Disinfected and Deodorized   |
| <input type="checkbox"/> Jet-Vac                                 | <input checked="" type="checkbox"/> Hydro Cleaned     |
| <input type="checkbox"/> Hand rodded                             | <input type="checkbox"/> Spread Lime on Affected Area |
| <input type="checkbox"/> Used Generator To Power Pumps/Equipment | <input type="checkbox"/> Public Notification          |
| <input type="checkbox"/> Other: Describe                         |   |

**Environmental Damage**

- |  |   |
|--|---|
| <input type="checkbox"/> OEHC - Observed or Evidence of Human Contact        | <input checked="" type="checkbox"/> NEAH - No Evidence of Adverse Health/Environmental Impact |
| <input type="checkbox"/> OEEI - Observed or Evidence of Environmental Impact | <input type="checkbox"/> EFK - Evidence of Fish Kill  |

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional  
Comments  
if Needed:

---

**CONFIRMATION NUMBER**

**FCCAC2DB-B19C-4100-9BD7-62382A35E39C**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** FCCAC2DB-B19C-4100-9BD7-62382A35E39C  
**Date Sent:** 2/10/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**  
 Date Overflow Began: **02/09/2014**  
 Date Overflow Ended: **02/09/2014**  
 Location:

Facility name:  
 Time:  
 Time:

**P Street**  
**12:00 pm**  
**02:45 pm**

**1223 & 1305 No. 47, between manholes S007-1650 & 1640, yard & building**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **cleanout & building**  
*(Enter overflow type if not listed)*

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:** **825 gallons**  
*(Give an estimate in gallons)*

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional  
 Comments  
 if Needed:



**CONFIRMATION NUMBER**

**397E1471-ADC7-409F-A50F-230927CEDBB8**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 397E1471-ADC7-409F-A50F-230927CEDBB8

**Date Sent:** 2/8/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0021750**  
 Date Overflow Began: **02/08/2014**  
 Date Overflow Ended: **02/08/2014**  
 Location: **3205 So. 96, between manholes RB01-0550 & 0540, yard**

Facility name: **Massard**  
 Time: **10:00 am**  
 Time: **11:07 am**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow

Other Overflow Type: **clean out**  
 (Enter overflow type if not listed)

**Volume:** **335**  
 (Give an estimate in gallons)

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded  Disinfected and Deodorized
- Jet-Vac  Hydro Cleaned
- Hand rodded  Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment  Public Notification
- Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact  NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact  EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

**CONFIRMATION NUMBER**

**FCB94616-17E7-4085-9D35-A99B1D793F95**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** FCB94616-17E7-4085-9D35-A99B1D793F95

**Date Sent:** 2/8/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street**

Date Overflow Began: **02/07/2014**

Time:

**02:45 pm**

Date Overflow Ended: **02/07/2014**

Time:

**06:00 pm**

Location: **2620 Riviera Cir., manholes RL01- 0760 & 0749, yard**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:**

**975**

*(Give an estimate in gallons)*

**Impact of SSO Event:**

**SSO Affected Private Property (ground)**

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & J).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEL - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

**CONFIRMATION NUMBER**

**E702A590-EEE4-4ED8-BECC-78403E9D9853**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** E702A590-EEE4-4ED8-BECC-78403E9D9853  
**Date Sent:** 2/7/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**  
 Date Overflow Began: **02/07/2014**  
 Date Overflow Ended: **02/07/2014**  
 Location: **3112 Emrich, manhole FL02-1560, ditch**

Facility name:  
 Time:  
 Time:

**P Street**  
**10:30 am**  
**11:30 am**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:** **300**

(Give an estimate in gallons)

**Impact of SSO Event:** **SSO Reached Public Land Only (ground)**

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional  
 Comments  
 if Needed:

**CONFIRMATION NUMBER**

**A837DDE8-2471-40FA-81FC-3DA9B7DE3B82**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** A837DDE8-2471-40FA-81FC-3DA9B7DE3B82

**Date Sent:** 2/6/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**  
 Date Overflow Began: **02/05/2014**  
 Date Overflow Ended: **02/05/2014**  
 Location:

Facility name:  
 Time:  
 Time:

**P Street**  
**04:42 pm**  
**05:22 pm**

**428 Melrose, between manholes P008-1375 & 1370, yard**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Volume: 200**

*(Give an estimate in gallons)*

**Impact of SSO Event: SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe **repaired**
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah** Title **Superintendent** Telephone Number **(479) 784-2344**

Additional Comments if Needed: **plumber damaged sewer service line while investigation stoppage called in by resident**

**CONFIRMATION NUMBER**

**08ADD39D-3F44-444D-920A-AAEE5608BD87**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 08ADD39D-3F44-444D-920A-AAEE5608BD87

**Date Sent:** 2/3/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0021750**  
 Date Overflow Began: **2/2/2014**  
 Date Overflow Ended: **2/2/2014**  
 Location: **3128 Glen Flora Way, between manholes Z004 1100 & 1090, yard**

Facility name: **Massard**  
 Time: **8:40 am**  
 Time: **10:20 am**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Volume:** **500**

*(Give an estimate in gallons)*

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Mitchell Vinsant**

Title **Supervisor**

Telephone Number **(479) 784-2347**

Additional  
Comments  
if Needed:

From: (479) 784-2330  
Steve Floyd  
City of Fort Smith  
3900 Kelley Highway

Origin ID: FSMA



Ship Date: 21MAR14  
ActWgt: 0.5 LB  
CAD: 1731127/INET3490

Fort Smith, AR 72904



J14101402070326

Delivery Address Bar Code



SHIP TO: (501) 682-0638 **BILL SENDER**  
**NPDES Enforcement Section, Water**  
**ADEQ**  
**5301 Northshore Drive**

Ref #  
Invoice #  
PO #  
Dept #



North Little Rock, AR 72118

**TUE - 25 MAR AA**  
**\*\* 2DAY \*\***

TRK# 7982 9241 9195  
0201

**72118**  
AR-US  
LIT

**SA LITA**



522G1UCC4FF220

**After printing this label:**

1. Use the 'Print' button on this page to print your label to your laser or inkjet printer.
2. Fold the printed page along the horizontal line.
3. Place label in shipping pouch and affix it to your shipment so that the barcode portion of the label can be read and scanned.

**Warning:** Use only the printed original label for shipping. Using a photocopy of this label for shipping purposes is fraudulent and could result in additional billing charges, along with the cancellation of your FedEx account number. Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com. FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery, misdelivery, or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim. Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental, consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss. Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our ServiceGuide. Written claims must be filed within strict time limits, see current FedEx Service Guide.

*FSMA21*