

Monthly SSO Report January 2014

Permit Number	Manhole Number	Location	Receiving Water	Duration	Cause	Volume	Component	Date	Started	Stopped	Steps Taken
AR0033278	between FL02-1370 & 1350	4517 Virginia	yard	60 minutes	line failure	300 gallons	line	1/2/2014	11:00 AM	12:00 PM	Hydro cleaned, repaired planned
AR0033278	manhole Z003-1370	8613 So. 30 Ter.	yard	175 minutes	line failure	875 gallons	manhole	1/6/2014	11:10 AM	2:05 PM	Hydro cleaned, repaired planned
AR0033278	between P004-0150 & 0100	1822 No. 13	yard	60 minutes	roots	300 gallons	cleanout	1/7/2014	12:10 PM	1:10 PM	Machine rodded
AR0021750	between MC06-0800 & 0790	1801 Utica	yard	55 minutes	grease & roots	275 gallons	cleanout	1/10/2014	1:50 PM	2:45 PM	Machine rodded
AR0033278	manhole Z005-1220	1816 Bramble Brae	yard	536 minutes	roots	13,400 gallons	manhole	1/10/2014	4:39 PM	1:35 AM	Hydro cleaned
AR0033278	between MC05-0640 & 0630	4209 Jennylind	ditch	96 minutes	grease	480 gallons	cleanout	1/12/2014	2:39 PM	4:15 PM	Machine rodded
AR0033278	manhole Z005-1140	1600 Bramble Brae	yard	130 minutes	roots	3,250 gallons	manhole	1/12/2014	4:50 PM	7:00 PM	Hydro cleaned
AR0021750	between P004-0860 & 0850	No. 31 & Brewer	ditch	100 minutes	line failure	500 gallons	line	1/17/2014	9:40 AM	11:20 AM	Emergency Repair
AR0033278	manhole S009-0820	3515 No. 50	yard	45 minutes	grease	225 gallons	manhole	1/22/2014	11:15 AM	12:30 PM	Hydro cleaned
AR0033278	manhole S007-0430	1800 No. 45 Ter.	storm drain	25 minutes	debris	125 gallons	manhole	1/23/2014	10:35 AM	11:00 AM	Machine rodded
AR0033278	between MC05-0780 & 0720	3714 Old Jennylind	yard	75 minutes	roots, grease & debris	375 gallons	cleanout	1/23/2014	3:55 PM	5:10 PM	Machine rodded
AR0033278	manhole S006-1610	1301 No. 48	yard	45 minutes	debris	225 gallons	manhole	01/24/2014	1:05 PM	1:50 PM	Machine rodded
AR0021750	manhole S004-0240	5900 Ellsworth	ditch	65 minutes	grease	325 gallons	manhole	1/26/2014	1:40 PM	2:45 PM	Hydro cleaned
AR0021750	manhole Z006-0930	102 Georgetown Ln.	yard	15 minutes	roots	75 gallons	manhole	1/27/2014	10:00 AM	10:35 AM	Hydro cleaned
AR0033278	between MC05-0158 & 0150	3301 Towson	storm drain	35 minutes	roots & debris	175 gallons	cleanout	1/27/2014	9:25 AM	10:00 AM	Machine rodded
AR0033278	manhole MC04-0085	3600 Wheeler	paved area	45 minutes	grease	45 gallons	manhole	1/28/2014	1:00 PM	1:45 PM	Hydro cleaned
AR0021750	between P009-0230 & 0220	1606 So. 29	ditch	60 minutes	roots	300 gallons	cleanout	1/30/2014	4:20 PM	5:20 PM	Machine rodded

**CONFIRMATION NUMBER**

**DD7124B0-1DBF-4C41-832E-9A9E1823C2E1**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** DD7124B0-1DBF-4C41-832E-9A9E1823C2E1

**Date Sent:** 1/3/2014

SSO  Bypass  Upset

Facility Permit Number:

**AR0033278**

Facility name:

**P Street**

Date Overflow Began:

**01/02/2014**

Time:

**11:00 am**

Date Overflow Ended:

**01/02/2014**

Time:

**12:00 pm**

Location:

**4517 Virginia, between manhole FL02-1370 & 1350, yard**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Volume:**

**300**

(Give an estimate in gallons)

**Impact of SSO Event:**

**SSO Reached Public Land Only (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**repaired planned**

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEL - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

**CONFIRMATION NUMBER**

**57C08D3F-FAC1-4E2A-BD54-1534B948F929**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 57C08D3F-FAC1-4E2A-BD54-1534B948F929

**Date Sent:** 1/7/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**  
 Date Overflow Began: **01/06/2014**  
 Date Overflow Ended: **01/06/2014**  
 Location: **8613 So. 30 Ter., manhole 2003-1370, yard**

Facility name:  
 Time:  
 Time:

**P Street**  
**11:10 am**  
**02:05 pm**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Volume: 875**

(Give an estimate in gallons)

**Impact of SSO Event: SSO Reached Receiving Water (river,stream)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe **repair scheduled, pipe is flowing**
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

**CONFIRMATION NUMBER**

**A3720113-8297-41D4-8618-698CE1BF824B**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** A3720113-8297-41D4-8618-698CE1BF824B  
**Date Sent:** 1/7/2014

SSO  Bypass  Upset

**Facility Permit Number:** AR0033278  
**Date Overflow Began:** 01/07/2014  
**Date Overflow Ended:** 01/07/2014  
**Location:**

**Facility name:**  
**Time:**  
**Time:**

**P Street**  
**12:10 pm**  
**01:10 pm**

**1822 No. 13, between manholes P004-0150 & 0100, yard**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **clean out**

(Enter overflow type if not listed)

**Volume:** 300

(Give an estimate in gallons)

**Impact of SSO Event:** SSO Affected Private Property (ground)

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded  Disinfected and Deodorized
- Jet-Vac  Hydro Cleaned
- Hand rodded  Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment  Public Notification
- Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact  NEAH - No Evidence of Adverse Health/Environmental Impact
- OE EI - Observed or Evidence of Environmental Impact  EFK - Evidence of Fish Kill

**Reported By** Leroy Jeremiah

**Title** Superintendent

**Telephone Number** (479) 784-2344

**Additional Comments if Needed:**

**CONFIRMATION NUMBER**

**C7B2732E-4C15-4AC3-B29B-2A5F2F24C641**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** C7B2732E-4C15-4AC3-B29B-2A5F2F24C641

**Date Sent:** 1/10/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0021750**

Facility name:

**Massard WWTP**

Date Overflow Began: **01/10/2014**

Time:

**01:50 pm**

Date Overflow Ended: **01/10/2014**

Time:

**02:45 pm**

Location: **1801 Utica Street, cleanout. Overflow into yard. Odo-ban applied, cleanup scheduled. Main line stoppage due to roots/grease. Basin MC06 USMH 0800 DSMH 0790**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Volume:** **275**

*(Give an estimate in gallons)*

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Steve Floyd1**

Title **Superintendent**

Telephone Number **(479) 784-2331**

Additional Comments if Needed:

**CONFIRMATION NUMBER**

**AA26936F-B2FB-4870-A797-ACDF909EFD0E**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** AA26936F-B2FB-4870-A797-ACDF909EFD0E

**Date Sent:** 1/11/2014

SSO  Bypass  Upset

**Facility Permit Number:** AR0033278  
**Date Overflow Began:** 01/10/2014  
**Date Overflow Ended:** 01/10/2014  
**Location:** 1816 Bramble Brae, manhole Z005-1220, yard

**Facility name:**  
**Time:**

**P Street**  
**04:39 pm**  
**01:35 am**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Volume:** 13,400

(Give an estimate in gallons)

**Impact of SSO Event:** SSO Reached Public Land Only (ground)

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

**Reported By** Leroy Jeremiah

**Title** Superintendent

**Telephone Number** (479) 784-2344

**Additional Comments if Needed:**

**CONFIRMATION NUMBER**

**4C7DD499-F0CF-44CC-B701-070545285394**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 4C7DD499-F0CF-44CC-B701-070545285394  
**Date Sent:** 1/13/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**  
 Date Overflow Began: **01/12/2014**  
 Date Overflow Ended: **01/12/2014**  
 Location: **4209 Jennylind, bwtweem nabholes MC05-0640 & 0630, ditch**

Facility name:  
 Time:  
 Time:

**P Street**  
**02:39 pm**  
**04:15 pm**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **clean out**

(Enter overflow type if not listed)

**Volume:**

(Give an estimate in gallons)

**Impact of SSO Event: SSO Reached Public Land Only (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded  Disinfected and Deodorized
- Jet-Vac  Hydro Cleaned
- Hand rodded  Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment  Public Notification
- Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact  NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact  EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional  
 Comments  
 if Needed:

**CONFIRMATION NUMBER**

**24E5B6D5-9B94-4D65-98D2-5EB2863E779C**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 24E5B6D5-9B94-4D65-98D2-5EB2863E779C

**Date Sent:** 1/13/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street**

Date Overflow Began: **01/12/2014**

Time:

**04:50 pm**

Date Overflow Ended: **01/12/2014**

Time:

**07:00 pm**

Location: **1600 Bramble Brae, Z005-1140, yard**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Volume: 3,250**

(Give an estimate in gallons)

**Impact of SSO Event: SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:



**CONFIRMATION NUMBER**

**C3E221D4-2DD7-4F71-9BAB-37EF5A581AB0**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** C3E221D4-2DD7-4F71-9BAB-37EF5A581AB0

**Date Sent:** 1/17/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street**

Date Overflow Began: **01/17/2014**

Time:

**09:40 am**

Date Overflow Ended: **01/17/2014**

Time:

**11:20 am**

Location:

**No. 31 & Brewer, between manholes P004-0860 & 0850, ditch**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Volume:**

**500**

(Give an estimate in gallons)

**Impact of SSO Event:**

**SSO Reached Public Land Only (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Emergency repair made**

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEL - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

**CONFIRMATION NUMBER**

**3E325ACE-8046-4E9F-9008-4BDC6FF3760C**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 3E325ACE-8046-4E9F-9008-4BDC6FF3760C

**Date Sent:** 1/23/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**  
 Date Overflow Began: **01/22/2014**  
 Date Overflow Ended: **01/22/2014**  
 Location: **3515 No. 50, manhole S009-0820, yard and building**

Facility name:  
 Time:  
 Time:

**P Street**  
**11:15 am**  
**12:30 pm**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **building**

(Enter overflow type if not listed)

**Volume: 225**

(Give an estimate in gallons)

**Impact of SSO Event: SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed: Owners provided copy of city damage claim policy

**CONFIRMATION NUMBER**

**C3544E89-B397-45BB-8772-4073B1893C4C**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** C3544E89-B397-45BB-8772-4073B1893C4C

**Date Sent:** 1/23/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street**

Date Overflow Began: **01/23/2014**

Time:

**10:35 am**

Date Overflow Ended: **01/23/2014**

Time:

**11:00 am**

Location: **1800 No. 45 Ter., manhole S007-0430, storm drain**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Volume:**

**125**

(Give an estimate in gallons)

**Impact of SSO Event:**

**SSO Reached Public Land Only (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OE EI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

**CONFIRMATION NUMBER**

**5F1E1AC2-D159-4686-9FDE-07A877125FA4**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#: 5F1E1AC2-D159-4686-9FDE-07A877125FA4**

**Date Sent: 1/24/2014**

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**  
 Date Overflow Began: **01/23/2014**  
 Date Overflow Ended: **01/23/2014**  
 Location: **3714 Jennylind, between MC05-0780 & 0720, yard**

Facility name:  
 Time:  
 Time:

**P Street**  
**03:55 pm**  
**05:10 pm**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **clean out**

*(Enter overflow type if not listed)*

**Volume: 375**

*(Give an estimate in gallons)*

**Impact of SSO Event: SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded  Disinfected and Deodorized
- Jet-Vac  Hydro Cleaned
- Hand rodded  Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment  Public Notification
- Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact  NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact  EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional  
 Comments  
 if Needed:

**CONFIRMATION NUMBER**

**FA702F29-ED8C-4C59-BFC9-7438CB0479A7**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** FA702F29-ED8C-4C59-BFC9-7438CB0479A7

**Date Sent:** 1/24/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**  
 Date Overflow Began: **01/24/2014**  
 Date Overflow Ended: **01/24/2014**  
 Location: **1301 No. 48, manhole S006-1610, yard**

Facility name:  
 Time:  
 Time:

**P Street**  
**01:05 pm**  
**01:50 pm**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Volume:** **225**

*(Give an estimate in gallons)*

**Impact of SSO Event:** **SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional  
 Comments  
 if Needed:

**CONFIRMATION NUMBER**

**61000D11-C6E8-4194-A4E5-F53A45CEBFBD**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 61000D11-C6E8-4194-A4E5-F53A45CEBFBD

**Date Sent:** 1/27/2014

SSO  Bypass  Upset

Facility Permit Number:	<b>AR0021750</b>	Facility name:	<b>Massard</b>
Date Overflow Began:	<b>01/26/2014</b>	Time:	<b>01:40 pm</b>
Date Overflow Ended:	<b>01/26/2014</b>	Time:	<b>02:45 pm</b>
Location:	<b>5900 Ellsworth, manhole S004-0240, ditch</b>		

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Volume:** **325**

(Give an estimate in gallons)

**Impact of SSO Event:** **SSO Reached Public Land Only (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

**CONFIRMATION NUMBER**

**EC998DA6-0B95-4203-B284-8251665CB4D6**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** EC998DA6-0B95-4203-B284-8251665CB4D6

**Date Sent:** 1/27/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0021750**

Facility name:

**Massard**

Date Overflow Began: **01/27/2014**

Time:

**10:00 am**

Date Overflow Ended: **01/27/2014**

Time:

**10:35 am**

Location: **102 Georgetown Ln., manhole 2006-0930, yard**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Volume: 75**

(Give an estimate in gallons)

**Impact of SSO Event: SSO Affected Private Property (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded  Disinfected and Deodorized
- Jet-Vac  Hydro Cleaned
- Hand rodded  Spread Lime on Affected Area
- Used Generator To Power Pumps/Equipment  Public Notification
- Other: Describe

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact  NEAH - No Evidence of Adverse Health/Environmental Impact
- OEEI - Observed or Evidence of Environmental Impact  EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

**CONFIRMATION NUMBER**

**2753F075-10C9-4AE6-95D2-FC3D0638D551**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 2753F075-10C9-4AE6-95D2-FC3D0638D551

**Date Sent:** 1/27/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0033278**

Facility name:

**P Street**

Date Overflow Began: **01/27/2104**

Time:

**09:25 am**

Date Overflow Ended: **01/27/2014**

Time:

**10:00 am**

Location: **3301 Towson Ave., between manholes MC05-0158 & 0150, storm drain**

*(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).*

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

*(Enter overflow type if not listed)*

**Volume: 175**

*(Give an estimate in gallons)*

**Impact of SSO Event: SSO Reached Receiving Water (river,stream)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

*(Short term and long-term action, including clean-up and any plans to remediate I & I).*

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:



**CONFIRMATION NUMBER**

**E8392928-EE45-4C97-A4DF-86FD34B77FDA**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** E8392928-EE45-4C97-A4DF-86FD34B77FDA  
**Date Sent:** 1/28/2014

SSO  Bypass  Upset

Facility Permit Number:	<b>AR0033278</b>	Facility name:	<b>P Street</b>
Date Overflow Began:	<b>01/28/2014</b>	Time:	<b>01:00 pm</b>
Date Overflow Ended:	<b>01/28/2014</b>	Time:	<b>01:45 pm</b>
Location:	<b>3600 Wheeler Ave., MC04-0085, paved area</b>		

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type:

(Enter overflow type if not listed)

**Volume:** **225**

(Give an estimate in gallons)

**Impact of SSO Event:** **SSO Reached Public Land Only (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OEEI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By <b>Leroy Jeremiah</b>	Title <b>Superintendent</b>	Telephone Number <b>(479) 784-2344</b>
Additional Comments if Needed:		

**CONFIRMATION NUMBER**

**78CAEAEA-D793-4C35-9407-37A10F0EFA70**

(NOTE: You will need this number should you ever need to contact ADEQ concerning this report)

**The following information has been sent.**

[Close this window](#) [Print this page](#)

**24-Hour Sanitary Sewer Overflow Report**

**SSO ID#:** 78CAEAEA-D793-4C35-9407-37A10F0EFA70

**Date Sent:** 1/31/2014

SSO  Bypass  Upset

Facility Permit Number: **AR0021750**  
 Date Overflow Began: **01/30/2014**  
 Date Overflow Ended: **01/30/2014**  
 Location: **1606 So. 29, between P009-0230 & 0220, ditch**

Facility name: **Massard**  
 Time: **04:20 pm**  
 Time: **05:20 pm**

(Give address, manhole number-if numbered. Include where the overflow went-yard, ditch, stream, storm sewer, building, other).

**Type of Overflow**

- Manhole Overflow
- Lift Station Overflow
- Main Line Overflow
- Service Line Overflow
- Other Overflow Type: **cleanout**

(Enter overflow type if not listed)

**Volume:** **300**

(Give an estimate in gallons)

**Impact of SSO Event:** **SSO Reached Public Land Only (ground)**

**Cause of Overflow**

- I & I - Rainfall
- Roots
- Grease
- Debris
- Equipment Failure
- Construction
- Vandalism
- Power Failure
- Line Failure/Break
- Other Cause:

**Action Taken - Check all that apply**

(Short term and long-term action, including clean-up and any plans to remediate I & I).

- Machine rodded
- Jet-Vac
- Hand rodded
- Used Generator To Power Pumps/Equipment
- Other: Describe
- Disinfected and Deodorized
- Hydro Cleaned
- Spread Lime on Affected Area
- Public Notification

**Environmental Damage**

- OEHC - Observed or Evidence of Human Contact
- OE EI - Observed or Evidence of Environmental Impact
- NEAH - No Evidence of Adverse Health/Environmental Impact
- EFK - Evidence of Fish Kill

Reported By **Leroy Jeremiah**

Title **Superintendent**

Telephone Number **(479) 784-2344**

Additional Comments if Needed:

# FedEx<sup>®</sup> xpress

RT 177 1 A  
ST 3 5332 02.25

Extremely Urgent

5332 02.24  
RT TUE

Page 1 of 1

From: (479) 784-2330  
Steve Floyd  
City of Fort Smith  
3900 Kelley Highway  
Fort Smith, AR 72904

Origin ID: FSMA



Ship Date: 20FEB14  
ActWgt 0.5 LB  
CAD: 1731127/NET3490

Delivery Address Bar Code



SHIP TO: (501) 682-0638  
BILL SENDER  
NPDES Enforcement Section, Water  
ADEQ  
5301 Northshore Drive


North Little Rock, AR 72118

Ref #  
Invoice #  
PO #  
Dept #


TUE - 25 FEB AA  
EXPRESS SAVER

TRK# 7979 7655 5332  
0201

72118  
AR-US  
LIT



## SA LITA



522G1/562F/F220

er and  
ons and  
X  
ervice

Insert shipping  
document here.