

NON-COMPLIANCE REPORT

EPA, REGION 6
COMPLIANCE ASSURANCE AND ENFORCEMENT
1445 ROSS AVENUE
DALLAS, TX 75202-2733

ADEQ
NPDES ENFORCEMENT SECTION
5301 NORTHSORE DRIVE
NORTH LITTLE ROCK, AR 72118

RE: NPDES Permit No. AR0021750 Massard WWTP

Address: 1609 9th Street

City: Barling, Arkansas 72923

Contact: Jonathan Shipley, Treatment Program Manager Phone: 479-784-2331

<u>Date of Non-compliance</u>	<u>Parameter Exceeded</u>	<u>Quantity or Loading</u>	<u>Quantity or Concentration</u>	<u>Permit Limits</u>
November 2023	BOD	N/A	(1) – 7 day average Exceedance (1) - 30 day average Exceedance	45 mg/l – 7 day avg. 30 mg/l – 30 day avg.

We feel this problem was due to:

The cause of the BOD exceedances are as follows;

On 11/6/23 the aeration basin was taken out of service for cleaning and repairs. The basin was placed back in service on 11/17/23. We experienced an increase in our Effluent BOD during the time the basin was out of service.

Plan of correcting the problem in the following manner:

The day after the aeration basin was brought back on line, the Effluent BOD levels decreased and were within permit limits.

Time estimated to correct the problem:

This appears to be an isolated event, and has been corrected.


Lance McAvoy, Director of Water Utilities

Date: 12/15/2023