

# Discharge Monitoring Report (DMR)

AR0021750 DMR SSOs April 2021

Print Date: 5/13/2021

Print Time: 1:32 pm

Permit Number	Date SSO Started	Time SSO Started	Date SSO Stopped	Time SSO Stopped	Date SSO Reported	Location	Pipe Description	Manhole	Where SSO Went Into	Watershed	Type of SSO	Cause of SSO	Environmental Damage	Duration in Min.	Volume (Gallons)	Impact of SSO Incident	Steps Taken	Internal SSO ID	Web Confirmation Number
AR0021750	04/05/2021	7:40 am	04/05/2021	8:55 am	04/05/2021	4620 N J St	S006-0590 to S006-0580		Yard	N/A	Service Line	Grease	NEAH	75	75	Private PPTY (Ground)	Jet Clean.,Scheduled Cleanup,Disinfection Performed	21-0098	bbccb8e5-169b-4b0f-a686-367911ac1954
AR0021750	04/06/2021	3:30 pm	04/06/2021	3:55 pm	04/07/2021	5104 Birnie Ave	S005-0560 to S005-0550	S005-0560	Yard, Paved Area		Manhole	Grease	NEAH	25	1,250	Private PPTY (Ground)	Jet Clean.,Scheduled Cleanup,Disinfection Performed	21-0103	b36ab465-c3e8-447e-bc1a-fa11e0d8097a
AR0021750	04/09/2021	11:29 am	04/09/2021	1:10 pm	04/09/2021	9404 Enid St	M001-1410 to M001-1400	M001-1410	Yard	N/A	Manhole	Grease	NEAH	100	500	Private PPTY (Ground)	Jet Clean.,Scheduled Cleanup,Disinfection Performed	21-0105	4d0d4551-619b-4519-b4c8-660d935ed83e
AR0021750	04/19/2021	8:06 am	04/19/2021	9:00 am	04/19/2021	3100 S 80th St	M004-1040 to M004-1035		Yard, Paved Area	Massard Creek	Main Line	Other	NEAH	54	540	Receiving Water (Riv, Str)	Jet Clean.,Scheduled Cleanup,Disinfection Performed	21-0113	0efeda3b-82c6-4977-a242-7072f1ebcd0f
AR0021750	04/19/2021	1:44 pm	04/19/2021	3:00 pm	04/20/2021	1318 N 47th St	S007-1620 to S007-1610		Yard	N/A	Service Line	Grease	NEAH	75	75	Private PPTY (Ground)	Jet Clean.,Scheduled Cleanup,Disinfection Performed	21-0114	4ea28481-0aad-4bb3-ac72-a7e2e44d0237
AR0021750	04/24/2021	7:51 am	04/24/2021	9:31 am	04/24/2021	1422 N 56th Ter	S002-1590 to S002-1580		Yard, Paved Area	N/A	Service Line	Grease	NEAH	100	100	Private PPTY (Ground)	Jet Clean.,Scheduled Cleanup,Disinfection Performed	21-0116	4bcc0851-04da-4dad-badc-e62bd6aa7f10
AR0021750	04/26/2021	8:20 am	04/26/2021	9:00 am	04/27/2021	3925 Morris Dr	S007-0520 to S007-0510		Yard	N/A	Service Line	Grease	NEAH	40	40	Private PPTY (Ground)	Jet Clean.,Scheduled Cleanup,Disinfection Performed	21-0123	40ea4337-96ae-48cb-8931-fcbdee-78f340
AR0021750	04/26/2021	8:20 am	04/26/2021	9:30 am	04/26/2021	4019 Morris Dr	S007-0520 to S007-0510		Yard	N/A	Service Line	Grease	NEAH	70	140	Private PPTY (Ground)	Jet Clean.,Scheduled Cleanup,Disinfection Performed	21-0124	48b2ab99-f80a-4d70-8fe6-dcc694fcd75e
AR0021750	04/26/2021	8:20 am	04/26/2021	9:30 am	04/26/2021	4011 Morris Dr	S007-0520 to S007-0510	S007-0520	Yard	N/A	Manhole	Grease	NEAH	70	700	Private PPTY (Ground)	Jet Clean.,Scheduled Cleanup,Disinfection Performed	21-0125	e22a6a78-5ac0-4f76-84e3-6b3f60301a54
AR0021750	04/26/2021	12:13 pm	04/26/2021	3:30 pm	04/27/2021	2405 N 53rd St	S005-0420 to S005-0410	S005-0420	Storm Drain	City of Fort Smith to Arkansas River	Manhole	Grease	NEAH	197	3,940	Receiving Water (Riv, Str)	Jet Clean.,Scheduled Cleanup,Disinfection Performed	21-0126	f136dda3-0647-46f6-b2c1-bcb1588479ae
AR0021750	04/28/2021	12:36 pm	04/28/2021	1:25 pm	04/29/2021	9412 Gary St	M001-0750 to M001-0740		Building	N/A	Service Line	Grease	NEAH	49	98	Basement Backup	Jet Clean.,No Cleanup Performed,No Disinfection Performed	21-0129	4a8e4b46-a0d8-448e-9790-b54b05ad22dc
AR0021750	04/28/2021	2:53 pm	04/29/2021	12:30 pm	04/29/2021	9412 Gary St	M001-0750 to M001-0740		Yard	N/A	Service Line	Line Break	NEAH	2,017	10,085	Private PPTY (Ground)	Jet Clean,Power Rod,Scheduled Cleanup,No Disinfection Performed	21-0131	cf97d96d-a799-4915-8d29-edcf77f1860d
AR0021750	04/28/2021	9:00 pm	05/01/2021	7:23 am	04/29/2021	9422 Rogers Ave	M002-0180 to M002-0170	M002-0180	River, Stream, Creek	Massard Creek	Manhole	Rainfall	NEAH	3,503	963,325	Receiving Water (Riv, Str)	None Indicated.,Scheduled Cleanup,No Disinfection Performed	21-0135	95c5d645-04c3-4eca-a450-e72a3e2f45b5
AR0021750	04/28/2021	6:00 pm	04/29/2021	5:00 am	04/29/2021	N 56th St	S004-1140 to S004-1130	S004-1140	Storm Drain	City of Fort Smith to Arkansas River	Manhole	Rainfall	NEAH	660	33,000	Receiving Water (Riv, Str)	None Indicated.,Scheduled Cleanup,No Disinfection Performed	21-0137	175d7192-f408-44ec-8cdf-002b04927193
AR0021750	04/30/2021	10:23 am	04/30/2021	11:29 am	04/30/2021	3108 S 80th St	M004-1035 to M004-1030	M004-1035	Paved Area, River, Stream, Creek	Massard Creek	Manhole	Debris	NEAH	67	67	Receiving Water (Riv, Str)	Jet Clean.,Scheduled Cleanup,Disinfection Performed	21-0143	74d02345-9971-4c64-8960-eb9984e3e52b

15 TOTAL OVERFLOWS

1,013,935 TOTAL GALLONS SPILLED